

Meeting system strength requirements in NSW

Material Change in Circumstances final assessment

Region: New South Wales

Date of issue: 25 August 2026

Executive Summary

In July 2025, Transgrid published its Project Assessment Conclusions Report (PACR), which identified the preferred portfolio of solutions to manage system strength in NSW.¹ This material change in circumstances (MCC) Report presents Transgrid's reassessment of the system strength portfolio, taking into account updated information available since the PACR publication.

This Report is the final step in the MCC assessment process. Transgrid published a draft MCC Report on its website on 1 July 2026 for consultation. This final Report incorporates and responds to the feedback received during that consultation.

Summary of the system strength PACR

The PACR identified a preferred portfolio of individual system strength solutions, including:

- ten network synchronous condensers at Transgrid substations;
- modifications to 650 MW of non-network synchronous machines to enable synchronous condenser mode;
- up to 5 GW of non-network grid-forming BESS to support a stable voltage waveform for future renewables; and
- contracts with non-network synchronous machines to fill gaps in system strength where required.

Of the ten network synchronous condensers, the first five 'Phase 1' synchronous condensers were identified as necessary to close modelled system strength gaps expected after the retirement of Eraring Power Station. The supply, civil and enabling works for these 'Phase 1' synchronous condensers have already been awarded. This includes the supply of two smaller synchronous condenser units at each site to meet Transgrid's specifications. Four 'Phase 2' synchronous condensers were identified to prepare the power system for the retirement of the remaining NSW coal generators beyond Eraring Power Station. One further 'Phase 2' synchronous condenser was identified to support remediation of the South West Renewable Energy Zone (REZ).

A material change in circumstances has occurred since the PACR

In April 2026, Transgrid notified the Australian Energy Regulator (AER) that a reopening trigger specified in the PACR had been met. The trigger was met because the anticipated cost of synchronous condensers had increased by more than 30%.² Transgrid's notification also identified changes to two other key assumptions: the expected delivery timing of synchronous condensers and projected coal retirement dates. These changes may also constitute an MCC.³

¹ Transgrid, 2025, Meeting system strength requirements in NSW [PACR](#)

² Clause 5.16.4(z4)(2) of the National Electricity Rules (NER); [Meeting system strength requirements in NSW – Notification of Material Change in Circumstances Assessment](#), Transgrid, April 2026. Reopening trigger in the PACR was if "costs of synchronous condensers required for 2031/32 or after increase by significantly more than 30%"

³ NER 5.16.4(z4)(3).

In June 2026, in response to Transgrid's notification, the AER published a determination requiring Transgrid to:⁴

- (i) undertake a streamlined MCC assessment, drawing on the existing PACR analysis, using updated inputs and assumptions based on AEMO's latest 2026 ISP Step Change scenario;
- (ii) publish a draft statement on Transgrid's website setting out any changes to the PACR preferred option with supporting analysis and justification, on or before 24 June 2026;
- (iii) undertake a one-month consultation period upon publishing of the draft statement; and
- (iv) publish a final statement (this Report) no later than 24 August 2026 which includes details of the submissions received during consultation and how they have been incorporated into the assessment.

Purpose of this Report

This Report presents the final outcomes of the MCC assessment. It identifies the resulting changes to the preferred portfolio of system strength solutions, consistent with the AER's required actions, on the condition that the commercial feasibility of 'Phase 2' synchronous condensers is resolved. Transgrid published a draft MCC Report on 1 July 2026, which was subject to a one-month consultation period.

Nature of the material changes in circumstance

Expected cost increase for 'Phase 2' synchronous condensers

In April 2026, Transgrid submitted a revenue proposal to the AER for the accelerated 'Phase 1' synchronous condensers project under the Electricity Infrastructure Investment (EII) Act. This project includes the first five of the ten synchronous condensers identified in the PACR.⁵ The total cost of the 'Phase 1' project is \$1.13 billion (\$FY25), at an average of \$225 million per site.⁶ These costs include design, construction and enabling works, as well as the supply of synchronous condensers and balance of plant equipment.

The PACR estimated an average synchronous condenser cost of \$160 million (\$FY24, equivalent to \$163 million in \$FY25). The PACR notes that actual costs were estimated to be within -20% to +30% of the base capital cost estimate. 'Phase 1' synchronous condenser costs are 38% higher than the PACR estimate, which is therefore the basis for the reopening trigger being met.

This cost increase was driven by significant escalation in global demand and supply constraints for synchronous condensers and design and construction services. Transgrid expects 'Phase 2' synchronous condenser costs to be higher than 'Phase 1' costs, due to additional supply chain impacts associated with the conflict in the Middle East. Updated 'Phase 2' cost estimates have been incorporated into this MCC assessment, noting that considerable supply chain uncertainty remains.

Changes to two other key assumptions

Two other key assumptions used in the PACR have also changed:

- (i) **Delivery timing of 'Phase 2' synchronous condensers:** the PACR assumed that the first 'Phase 2' synchronous condensers would be delivered between March 2029 and February 2030. This MCC assessment assumes delivery at the beginning of FY34, reflecting additional

⁴ [Material change in circumstances – Meeting system strength requirements in NSW – Determination](#), AER, June 2026

⁵ [Transgrid System Strength Project \(hybrid\)](#), Transgrid, April 2026


⁶ The revenue proposal stated a cost of \$1.19 billion, based on a dollar cost basis of September 2026 related to the regulatory year basis of that proposal. All costs for this MCC assessment are shown on 30 June 2025 dollars.

regulatory processes, including the dispute on Transgrid's PACR,⁷ this MCC assessment, the risk of further MCC assessments, and longer manufacturing lead times.

- (ii) **Coal retirement dates:** AEMO's latest 2026 ISP Step Change scenario projects later retirement dates for NSW coal generating units than the 2024 ISP, which informed Transgrid's system strength PACR.

This MCC assessment has also compared the results under coal retirement dates announced by their owners ('Proponent Advised' dates), as presented in Figure 1.

Figure 1. Comparison of NSW coal unit retirement schedule forecasts



Technical and commercial feasibility of solutions assessed

This MCC assessment focuses on the need that the PACR addressed through the 'Phase 2' synchronous condensers. Table 1 summarises the feasible solutions assessed in this MCC assessment.

Table 1. Comparison of feasibility and timing of available options

Technology	Feasibility	Timing
'Phase 2' synchronous condensers	Technically feasible, however, not currently commercially feasible. The current cost of finance is higher than the compensation available under the regulatory regime.	If commercially feasible, synchronous condensers could be operational in FY34, under an assumed delivery timing which follows the standard NER process. An accelerated process could deliver the project in FY31, if commercial feasibility can be resolved.

⁷ Following the PACR publication, the AER received a notice of dispute on Transgrid's system strength PACR in August 2025 and published its determination on the [dispute](#) in December 2025.

Technology	Feasibility	Timing
Grid-forming BESS for the minimum level of system strength	Grid-forming BESS are not currently considered technically feasible to provide protection-quality levels of fault current. ⁸ However, independent advice from Aurecon anticipates that grid-forming BESS may become feasible to meet minimum level requirements from FY33.	Noting technical feasibility has not been confirmed, grid-forming BESS for the minimum level have been included in the assessment from FY33, but only to the extent that there are sufficient fallback solutions to meet the system strength need if grid-forming BESS do not perform as anticipated.
Re-dispatch of synchronous machines (hydro, gas) ⁹	Technically and commercially feasible, up to a defined limit for gas generators based on pipeline and gas supply constraints.	Available immediately in all portfolio options for existing plant or at in-service date for committed and anticipated generators.

Commercial feasibility of ‘Phase 2’ synchronous condensers

Currently, the actual cost of funding projects is higher than that provided for in the AER’s rate of return instrument (RORI). This creates an investability issue with no clear solution under the NER. We will continue to engage with the AER to assess our options, including any flexibility that the AER may have when making a contingent project determination. Transgrid has highlighted this issue on several occasions and most recently during the AER’s draft RORI consultation process.¹⁰

In past large projects, Transgrid has worked with the AER and various government agencies to close the gap with additional support or alternative approval pathways, successfully reaching financial close. Transgrid plans to take the same approach for capital investments contemplated in this MCC.

Modelling approach and portfolio formation

In this MCC assessment, Transgrid manually constructed five portfolio options to assess the incremental value of each ‘Phase 2’ synchronous condenser and identify the portfolio that maximises net market benefits.¹¹ Portfolio option 1 contains one ‘Phase 2’ synchronous condenser, up to portfolio option 5 which contains all five ‘Phase 2’ synchronous condensers. The base case contains no ‘Phase 2’ synchronous condensers.

For each portfolio option, power system modelling identified any projected shortfall against the minimum level of system strength requirements. The modelling included existing and committed sources of system strength, as well as the relevant ‘Phase 2’ synchronous condensers. Transgrid then identified the hydro and gas unit re-dispatch required to meet system strength requirements for each option. A net economic benefit assessment was used to identify the solutions in the preferred portfolio, assuming the technical and/or commercial feasibility of each solution is established.

⁸ This is based on AEMO’s public position (AEMO, May 2024, Update to the 2023 Electricity Statement of Opportunities and more recently, AEMO’s 2025 Transition plan for system security, December 2025, Page 135) and independent advice from Aurecon to support Transgrid’s system strength PACR (Advice on maturity of grid-forming inverter solutions for system strength, Aurecon, March 2024)

⁹ Transgrid defines ‘re-dispatch’ as an increase in the operating hours of synchronous generators to provide system strength, in addition to their typical energy market operations.

¹⁰ Transgrid, 31 July 2026, Submission on draft 2026 RORI, <https://www.aer.gov.au/documents/transgrid-submission-draft-2026-rori-31-july-2026>

¹¹ This is consistent with the AER’s June 2026 determination regarding Transgrid’s MCC notification, which required Transgrid to undertake a streamlined MCC assessment, drawing on the existing PACR analysis.

Modelling was undertaken in two stages:

- **Stage (a):** this stage excludes the potential contribution of grid-forming BESS to the minimum level of system strength, as they are not currently considered technically feasible for minimum level provision. Portfolio options in this stage are denoted with an 'a', for example, portfolio option 3a. Stage (a) identifies technically feasible portfolio options; only feasible portfolio options carry forward for subsequent assessment in stage (b).
- **Stage (b):** this stage includes the contribution of grid-forming BESS to the minimum level from FY33, assuming confirmation of their technical feasibility. This is because there is a high likelihood that grid-forming BESS could form part of the preferred portfolio option if their technical feasibility was confirmed. Portfolio options in this stage are denoted with a 'b', for example, portfolio option 3b. This stage involves the identification of the optimal amount of gas and hydro re-dispatch and grid-forming BESS for the minimum level for each credible portfolio option.

Transgrid proposes to rely on grid-forming BESS only to the extent that there are sufficient alternative fallback solutions available to meet the need, i.e. available re-dispatch of hydro and/or gas, if grid-forming BESS feasibility is not confirmed. This is to ensure the system security risk associated with the uncertainty of when, or if, grid-forming BESS will become a feasible solution for the minimum level is managed.

The assessment of whether sufficient fallback solutions exist occurs in stage (a). Where there are insufficient fallback solutions, i.e. modelling shows a risk of system strength gaps, portfolio options are not deemed technically feasible and were removed from the stage (b) assessment.

Stage (a) determines technically credible portfolio options

Table 2 shows the years where a modelled risk of system strength gaps is observed under the 2026 ISP Step Change scenario. Table 3 shows the same information when assessed with Proponent Advised coal unit retirement dates.

A modelled risk of system strength gaps is identified when the level of gas re-dispatch is considered infeasible, due to a breach in pipeline or supply constraints. Modelled gaps indicate a portfolio option is not technically feasible in a certain year, as there are insufficient system strength solutions to meet the need.

Table 2. 2026 ISP Step Change scenario. Modelled risk of system strength gaps when excluding grid-forming BESS

Assumed synchronous condenser timing (delivery in FY34)							Accelerated synchronous condenser timing (delivery in FY31)						
Portfolio option	Base case	1a	2a	3a	4a	5a	Portfolio option	Base case	1a	2a	3a	4a	5a
FY31	Risk	Risk					FY31	Risk	Risk	No risk	No risk	No risk	No risk
FY32	Risk	Note, 'Phase 2' synchronous condensers only available in FY34					FY32	Risk	No risk	No risk	No risk	No risk	No risk
FY33	Risk						FY33	Risk	Risk	No risk	No risk	No risk	No risk
FY34	Risk	Risk	Risk	No risk	No risk	No risk	FY34	Risk	Risk	Risk	No risk	No risk	No risk
FY35+	Risk	Risk	Risk	No risk	No risk	No risk	FY35+	Risk	Risk	Risk	No risk	No risk	No risk

Table 3. Proponent Advised coal unit retirement scenario. Modelled risk of system strength gaps when excluding grid-forming BESS

Assumed synchronous condenser timing (delivery in FY34)							Accelerated synchronous condenser timing (delivery in FY31)						
Portfolio option	Base case	1a	2a	3a	4a	5a	Portfolio option	Base case	1a	2a	3a	4a	5a
FY31	No risk	No risk <i>Note, 'Phase 2' synchronous condensers only available in FY34</i>					FY31	No risk	No risk	No risk	No risk	No risk	No risk
FY32	No risk						FY32	No risk	No risk	No risk	No risk	No risk	No risk
FY33	No risk						FY33	No risk	No risk	No risk	No risk	No risk	No risk
FY34	Risk	Risk	Risk	No risk	No risk	No risk	FY34	Risk	Risk	Risk	No risk	No risk	No risk
FY35+	Risk	Risk	Risk	No risk	No risk	No risk	FY35+	Risk	Risk	Risk	No risk	No risk	No risk

To assess whether a portfolio option is technically feasible, the assessment focuses on FY34 and beyond, when 'Phase 2' synchronous condensers are assumed to be available to meet the system strength need. From FY34 under both 2026 ISP Step Change (Table 2) and Proponent Advised coal unit retirement scenarios (Table 3), a modelled risk of system strength gaps is observed under the base case and in portfolio options 1a and 2a, for both the assumed and accelerated synchronous condenser timing. As such, these portfolio options, with less than three 'Phase 2' synchronous condensers, are deemed not technically feasible and are therefore excluded from the stage (b) assessment.

Table 2 also shows a modelled risk of gaps between FY31-33 if the acceleration of 'Phase 2' synchronous condensers does not occur (as shown in the left-hand table). Accelerating at least two 'Phase 2' synchronous condensers would close this gap (as shown in the right-hand table), with a third required before the start of FY34.

Table 3 indicates that the acceleration of 'Phase 2' synchronous condensers would not be needed if NSW coal generators operate until Proponent Advised dates, as there is no modelled risk of system strength gaps in the FY31-33 period, noting that three or more 'Phase 2' synchronous condensers are still required to close modelled gaps from FY34 onwards.

Figure 2 shows the net present value of economic benefits for each portfolio option under stage (a), including portfolio options 1a and 2a which are deemed not technically feasible, compared to a base case ('do nothing') scenario, under the 2026 ISP Step Change scenario. Under stage (a), portfolio option 4a, with four 'Phase 2' synchronous condensers, maximises net economic benefits and would be selected as the preferred portfolio under both the assumed (FY34) and accelerated (FY31) timing of synchronous condensers (should commercial feasibility be available).

Figure 2. 2026 ISP Step Change scenario. Net present value economic benefits in stage (a) assessment when excluding grid-forming BESS¹²




Figure 2 demonstrates that the net present value of economic benefits is significantly lower for portfolio options 1a and 2a (which are not credible) in comparison to portfolio 4a, approximately \$43 billion and \$21 billion respectively under both synchronous condenser delivery date scenarios. This outcome is primarily driven by the substantial costs associated with involuntary load curtailment, as portfolio options 1a and 2a do not have sufficient solutions available to meet system strength requirements. Note that results under Proponent Advised coal retirement dates are shown in Section 8.2; the ranking of portfolio options remains consistent with the 2026 ISP Step Change scenario.


Stage (b) identifies portfolio options that maximise net economic benefits

Stage (b) of the assessment only considers the technically feasible portfolio options which were selected for further assessment in stage (a), being portfolio options 3 to 5, which includes three or more 'Phase 2' synchronous condensers.

Figure 3 shows the net present value economic benefits assessment for technically feasible portfolio options 3b – 5b. Portfolio option 3b maximises net economic benefits, delivering \$44 billion in benefits under the assumed synchronous condenser timing (FY34), and \$45 billion under the accelerated synchronous condenser timing (FY31), when modelled under the 2026 ISP Step Change scenario and compared to the base case.

¹² To interpret the NPV charts, dark green bars represent benefits under the assumed delivery timing of 'Phase 2' synchronous condensers (in FY34). The benefits of accelerated synchronous condenser delivery (FY31) are represented as the summation of the benefits of the dark and light green bars (with the total noted above the light green bars).

Figure 3. 2026 ISP Step Change scenario. Net present value economic benefits assessment in stage (b), including grid-forming BESS



Based on the stage (b) assessment, the preferred portfolio option is portfolio option 3b, which includes three 'Phase 2' synchronous condensers and 900 MW of grid-forming BESS for the minimum level of system strength, conditional on resolving the commercial feasibility of 'Phase 2' synchronous condensers. Including grid-forming BESS for the minimum level (assuming technical feasibility is confirmed) reduces the preferred portfolio by one 'Phase 2' synchronous condenser.

The accelerated synchronous condenser timing (FY31) has a higher net present value of economic benefit than the assumed timing (FY34) for all portfolio options. For portfolio option 3b under the 2026 ISP Step Change scenario, the added economic benefit of acceleration is \$803 million. This increase in value is mostly attributed to avoided involuntary load curtailment where a modelled risk of system strength gaps was observed. This highlights the benefit of earlier delivery of the identified solutions, if feasible.

Portfolio option 3b has \$117 million higher net economic benefits, under the accelerated synchronous condenser scenario, than the optimal portfolio without grid-forming BESS (portfolio option 4a). This demonstrates the increased value of including grid-forming BESS in the portfolio and justifies shifting the preferred option from portfolio option 4a to portfolio option 3b. The increase in benefits is driven by the avoided capital and operating costs of the fourth synchronous condenser, as well as a reduced need and associated cost of gas re-dispatch.

Selection of the preferred portfolio of system strength solutions

This MCC assessment has identified the preferred portfolio option summarised in Table 4, conditional on the commercial feasibility of 'Phase 2' synchronous condensers being resolved.

Table 4. Details of the preferred portfolio option in this MCC assessment

Technology	Number	Timing	Location
‘Phase 2’ synchronous condensers	Three, dependent on commercial feasibility being resolved. Reduction from five in the PACR, to three.	To be delivered by FY34, following the assumed timing under the NER process, or earlier if feasible. If acceleration is feasible, by FY31 to close the modelled risk of system strength gaps between FY31-33, as modelled under the AEMO 2026 ISP coal retirement timing.	Sites of the three ‘Phase 2’ synchronous condensers are Dinawan, Munmorah and Newcastle. ¹³
Grid-forming BESS	900 MW for the minimum level of system strength, once technical feasibility is confirmed. An increase from 0 MW for the minimum level, in addition to 5 GW for the efficient level that remains in the preferred portfolio.	Modelled from FY33 based on independent advice from Aurecon, but if technical feasibility can be proven earlier, this will increase benefits further.	Sydney West region – connected to the transmission network is considered most beneficial.
Modifications to synchronous machines to enable synchronous condenser mode	650 MW – as identified in the PACR. ¹⁴	From FY29	Projects located closer to the Sydney West node are considered more beneficial.

Consistent with the PACR, hydro and gas re-dispatch remains part of the preferred portfolio option, particularly in the early 2030s. The need for coal re-dispatch will be re-evaluated in the contracting timeframe. Transgrid will procure system security services from synchronous machines in the contracting timeframe based on latest information and unit availability from all technologies. The revised preferred portfolio option is the outcome of the cost-benefit analysis based on the latest information available at this time.

Consultation during this MCC assessment

Stakeholders were provided with a one-month consultation period on the draft MCC assessment, consistent with the AER’s determination. Transgrid received four submissions, from Lake Lyell Project, Castle Group, Andritz and several members of Transgrid’s Consumer Advisory Group. These submissions are published on Transgrid’s website alongside this Report.

¹³ Consistent with the PACR, the locations of synchronous condensers in the Sydney/Newcastle region may change as detailed site feasibility studies continue to ensure the optimal locations are progressed.

¹⁴ At this stage, no additional technically and commercially feasible options have materialised since the system strength PACR.

The submissions generally focused on:

- Support for the reassessment of the preferred portfolio including revision of the number of ‘Phase 2’ synchronous condensers from five to three.
- Providing additional information on emerging system strength solutions, including the Lake Lyell Pumped Hydro facility and a portfolio of grid-forming BESS projects.
- The importance of preserving flexibility to pivot from synchronous condensers to alternative solutions (e.g. new synchronous machines with synchronous condenser capability and grid-forming BESS once proven technically feasible for the minimum level of system strength), if in the interest of consumers.
- Further clarity of requirements for grid-forming BESS to demonstrate technical feasibility for the minimum level.

These submissions have been addressed in Section 3 and Appendix E of this final MCC Report. Transgrid thanks those involved in the consultation process during this MCC assessment, the RIT-T and during ongoing engagement for managing system strength in NSW.

Transgrid is seeking additional non-network solutions that could further change the preferred portfolio

Transgrid recognises that preserving optionality and flexibility is in consumers’ interests. Where technically and commercially feasible lower-cost alternatives emerge within the time required, Transgrid will seek to maintain the ability to pivot away from solutions in the preferred portfolio.

As a result of this MCC assessment, Transgrid has reduced the number of ‘Phase 2’ synchronous condensers in the portfolio – namely:

- The fifth ‘Phase 2’ synchronous condenser is no longer required because of the expected delay to the retirement of NSW coal generators as per the 2026 ISP, which provides sufficient time for the entry of synchronous condensers in Central West Orana REZ and the connection of new transmission projects which facilitates the flow of system strength in NSW.
- The fourth ‘Phase 2’ synchronous condenser has been removed because of the inclusion of 900 MW of grid-forming BESS for the minimum level into the portfolio (which increases net market benefits).

Transgrid has assessed three changes which could further reduce the number of ‘Phase 2’ synchronous condensers and increase net market benefits (subject to further criteria outlined in Section 12):

- If at least 500 MW of synchronous machines with synchronous condenser capability emerges in the Sydney / Newcastle region (or larger capacity but outside of the region). This is in addition to the 650 MW of synchronous machines with synchronous condenser capability across southern NSW that were identified in the PACR.
- If an additional 950 MW of grid-forming BESS for the minimum level (in addition to the 900 MW already included in the preferred portfolio of this MCC assessment) emerges in the Sydney / Newcastle region and there is additional evidence to confirm their technical feasibility such that fallback solutions are not required.
- If sufficient coal generator units extend their Proponent Advised retirement dates beyond 2033 and this is expected to be included in an AEMO ISP update.

Transgrid has also explored different coal unit retirement assumptions during this assessment, even beyond the proponent advised dates. If sufficient coal units were to extend their retirement dates beyond FY34, we expect the need for 'Phase 2' synchronous condensers will also be deferred commensurately, assuming a similar level of coal unit reliability and operational output could be maintained.

Deferred coal retirement dates in isolation are not expected to change the preferred portfolio composition, only the timing of the need for 'Phase 2' synchronous condensers and level of hydro and gas re-dispatch. However, any delay in coal unit retirement that results in deferred investment provides more time for alternative solutions, including grid-forming BESS or emerging synchronous machines with synchronous condenser capability, to demonstrate feasibility and/or become committed.

Next steps for system strength solutions

Transgrid will continue to investigate options that preserve flexibility. This includes working with industry to identify new non-network options that could become technically and commercially feasible and, if appropriate, support a further refinement of the preferred portfolio.

Grid-forming BESS

For the efficient level, Transgrid is currently evaluating responses to its initial tender for up to 2 GW of grid-forming BESS to support stable voltage waveform. Future tenders will occur as Transgrid progresses towards the PACR-identified portfolio of 5 GW; subject to holistic assessments of the need in the contracting timeframe.

For the minimum level, Transgrid is engaging with industry, AEMO and other network service providers to help progress the assessment and validation of the feasibility of grid-forming BESS to provide protection quality fault current, including as an industry partner to the University of New South Wales (UNSW) 'PROFILES' project.¹⁵

Transgrid invites proponents of all grid-forming BESS in NSW who are interested in participating in future system security service tenders and/or specifically those located in the Sydney West region and interested in supporting the minimum level technical feasibility assessment to contact Transgrid via email at systemstrength@transgrid.com.au, including a completed expression of interest (EOI) form.

Re-dispatch of synchronous machines

Transgrid has completed its initial tranche of contracts for synchronous system security services. The timing for a second tranche of contracts will be informed by additional market modelling. Transgrid invites proponents to maintain an up-to-date EOI with Transgrid for system strength services.

Transgrid welcomes EOIs from parties with solutions that include modifications to existing or new synchronous machines, including hydro, coal and gas units, to enable their operation in synchronous condenser mode. The upgrades to 650 MW of synchronous machines to enable synchronous condenser mode, which were identified in the PACR preferred portfolio, remain in the MCC preferred portfolio.

'Phase 2' synchronous condensers

At this stage, the cost of finance for the 'Phase 2' synchronous condensers is above the compensation provided under the existing regulatory arrangements. The next step is to explore how the gap between the actual cost of finance and the compensation can be closed. Further acceleration options can also be considered as part of this investigative work.

¹⁵ <https://arena.gov.au/projects/unsw-protection-relay-operation-for-inverter-based-low-inertia-electricity-systems-profiles-project/>

Transgrid will continue to monitor for future MCCs which could reshape the preferred portfolio option. Transgrid will also continue to explore options in the contracting timeframe to maintain flexibility to refine the preferred option further, if procurement of 'Phase 2' synchronous condensers was to proceed.

Contents

Executive Summary	2
Summary of the system strength PACR	2
A material change in circumstances has occurred since the PACR.....	2
Purpose of this Report.....	3
Nature of the material changes in circumstance	3
Technical and commercial feasibility of solutions assessed	4
Commercial feasibility of ‘Phase 2’ synchronous condensers	5
Modelling approach and portfolio formation	5
Stage (a) determines technically credible portfolio options	6
Stage (b) identifies portfolio options that maximise net economic benefits	8
Selection of the preferred portfolio of system strength solutions	9
Consultation during this MCC assessment	10
Transgrid is seeking additional non-network solutions that could further change the preferred portfolio .	11
Next steps for system strength solutions	12
Disclaimer	17
1. Context and purpose	19
1.1. Purpose of this Report.....	19
1.2. Transgrid’s system strength obligations.....	20
1.3. Timeline of activities to date for managing system strength in NSW	21
2. Nature of the material changes in circumstances.....	23
2.1. MCC reopening trigger addressed in this assessment	23
2.1.1. Increase in synchronous condenser capital costs	23
2.2. Other changes in key assumptions included in this assessment	23
2.2.1. Timing of earliest synchronous condenser delivery	24
2.2.2. Changes to coal unit retirement dates and operational assumptions	24
2.3. Other changes to assumptions which are not material to this assessment.....	26
2.3.1. Eraring Power Station extension	26
2.3.2. Changes to Inverter-based resources (IBR) forecasts.....	26
3. Consultation on the Draft MCC Report	28
4. Individual solutions assessed	29
4.1. Synchronous condensers.....	30
4.1.1. Drivers for cost and delivery timing assumption changes for synchronous condensers	30
4.1.2. Commercial feasibility of ‘Phase 2’ synchronous condensers	32

4.1.3. Basis for assessing two synchronous condenser delivery timings	32
4.1.4. Revised assumptions for 'Phase 2' synchronous condensers	33
4.2. Grid-forming BESS contribution towards minimum level requirements	34
4.2.1. Projected timing of technically feasible grid-forming BESS contribution towards minimum level requirements	35
4.2.2. Location of grid-forming BESS projects	36
4.2.3. Costs applied to grid-forming BESS solutions	36
4.3. Re-dispatch of synchronous generators	37
4.3.1. Hydro	37
4.3.2. Gas generators	37
4.3.3. Coal generators	38
5. Modelling approach and assumptions	39
5.1. Coal unit retirement dates	39
5.2. Treatment of New England Renewable Energy Zone	40
5.3. Treatment of the Dinawan synchronous condenser	41
5.4. Representation of the base case	42
5.5. Net market benefit assessment.....	43
5.5.1. Types of market benefits	43
5.5.2. Cost benefit analysis parameters adopted.....	44
6. Portfolio formation methodology	46
6.1.1. Identifying the number of synchronous condensers	46
6.1.2. Identifying the amount of hydro and gas re-dispatch.....	46
6.1.3. Identifying the amount of grid-forming BESS for the minimum level	46
7. Portfolio options.....	48
7.1. Stage (a) determines technically feasible portfolio options	48
7.1.1. Difference in re-dispatch requirements between 2026 ISP Step Change and Proponent Advised coal unit retirement date scenarios between FY31-34.....	52
7.1.2. Re-dispatch from FY34 onwards.....	52
7.1.3. Risk of system strength gaps	53
7.2. Stage (b) identifies the optimal amount of grid-forming BESS for the minimum level.....	54
8. Net market benefits assessment	57
8.1. 2026 ISP Step Change coal unit retirement dates scenario	57
8.1.1. Net market benefits excluding grid-forming BESS for the minimum level	57
8.1.2. Net market benefits including grid-forming BESS for the minimum level	59
8.1.3. Portfolio costs including grid-forming BESS	61
8.2. Proponent Advised coal unit retirement dates scenario	62
8.2.1. Net market benefits excluding grid-forming BESS for the minimum level	63

8.2.2. Net market benefits including grid-forming BESS for the minimum level	64
8.3. Discussion of coal unit retirement dates	65
8.4. Inertia assessment	66
9. Case studies	67
9.1. Case study 1: Asymmetric risk of system strength adequacy at transition points.....	67
9.2. Case study 2: System strength adequacy with reduced coal unit output	69
10. Sensitivity analysis	72
10.1. New England REZ sensitivity	72
10.1.1. New England REZ planning uncertainty	72
10.1.2. Sensitivity assumptions	73
10.1.3. Sensitivity results.....	73
10.2. Sensitivity on higher and lower 'Phase 2' synchronous condensers costs	74
11. Selecting the preferred portfolio	75
12. Additional non-network options could further change the optimal portfolio in the future	77
12.1. Non-network solutions already within the revised preferred portfolio	77
12.2. Possible alternative solutions to 'Phase 2' synchronous condensers if proven technically and commercially feasible	77
12.2.1. Synchronous machines with synchronous condenser mode enablement.....	78
12.2.2. Grid-forming BESS for the minimum level	79
12.2.3. Coal generator units	79
13. Next steps for managing system strength requirements	81
13.1. Consultation.....	81
13.2. Proposed next steps for system strength solutions	81
13.2.1. Non-network solutions	81
13.2.2. Network synchronous condensers	82
Appendix A. MCC assessment modelled scenario and input parameters	83
Appendix B. Assessment of gas availability for system strength re-dispatch.....	85
Appendix C. Comparison of net present value methodology	89
Appendix D. Compliance checklist	91
Appendix E. Details of non-confidential points raised in consultation on the draft MCC Report	93

Disclaimer

This suite of documents comprises Transgrid's streamlined assessment for assessing material changes in circumstances for the meeting system strength requirements in NSW project. It has been prepared and made available solely for information purposes. It is made available on the understanding that Transgrid and/or its employees, agents and consultants are not engaged in rendering professional advice. Nothing in these documents is a recommendation in respect of any possible investment.

The information in these documents reflects the forecasts, proposals and opinions adopted by Transgrid at the time of publication, other than where otherwise specifically stated. Those forecasts, proposals and opinions may change at any time without warning. Anyone considering information provided in these documents, at any date, should independently seek the latest forecasts, proposals and opinions.

These documents include information obtained from the Australian Energy Market Operator (AEMO) and other sources. That information has been adopted in good faith without further enquiry or verification. The information in these documents should be read in the context of the Electricity Statement of Opportunities, the Integrated System Plan, the Transition Plan for System Security and the Gas Statement of Opportunities published by AEMO and other relevant regulatory consultation documents.

These documents do not purport to contain all the information that AEMO, a prospective investor, Registered Participant or potential participant in the National Electricity Market (NEM), or any other person may require for making decisions. In preparing these documents it is not possible, nor is it intended, for Transgrid to have regard to the investment objectives, financial situation and particular needs of each person or organisation which reads or uses this document. Anyone proposing to rely on or use the information in this document should:

1. Independently verify and check the currency, accuracy, completeness, reliability and suitability of that information.
2. Independently verify and check the currency, accuracy, completeness, reliability and suitability of reports relied on by Transgrid in preparing these documents.
3. Obtain independent and specific advice from appropriate experts or other sources.

Accordingly, Transgrid makes no representations or warranty as to the currency, accuracy, reliability, completeness or suitability for particular purposes of the information in this suite of documents. Persons reading or utilising this suite of documents acknowledge and accept that Transgrid and/or its employees, agents and consultants have no liability for any direct, indirect, special, incidental or consequential damage (including liability to any person by reason of negligence or negligent misstatement) for any damage resulting from, arising out of or in connection with, reliance upon statements, opinions, information or matter (expressed or implied) arising out of, contained in or derived from, or for any omissions from the information in this document, except insofar as liability under any New South Wales and Commonwealth statute cannot be excluded.

Privacy notice

Transgrid is bound by the Privacy Act 1988 (Cth). In making submissions in response to this consultation process, Transgrid will collect and hold personal information for the purpose of receiving and following up on submissions, including name, email address, employer and phone number.

Under the National Electricity Law, there are circumstances where Transgrid may be compelled to provide information to the Australian Energy Regulator (AER). Transgrid will advise you should this occur.

Transgrid's Privacy Policy sets out the approach to managing personal information. In particular, it explains how you may seek to access or correct the personal information held about you, how to make a complaint about a breach of Transgrid's obligations under the Privacy Act, and how Transgrid will deal with complaints. You can access the Privacy Policy here (<https://www.transgrid.com.au/Pages/Privacy.aspx>).

1. Context and purpose

1.1. Purpose of this Report

In July 2025, Transgrid completed a Regulatory Investment Test for Transmission (RIT-T) for the *Meeting System Strength Requirements in NSW* project. The Project Assessment Conclusions Report (PACR) identified a preferred portfolio option composed of:

- ten network synchronous condensers at Transgrid substations;
- modifications to 650 MW of non-network synchronous machines to enable synchronous condenser mode;
- up to 5 GW of non-network grid-forming battery energy storage systems (BESS) to support a stable voltage waveform for future renewables; and
- contracts with non-network synchronous machines to fill gaps in system strength where required.

Of the ten network synchronous condensers identified as required in the PACR, the first five 'Phase 1' synchronous condensers were required to close modelled system strength gaps that occur following the retirement of Eraring Power Station. The supply, civil and enabling works for 'Phase 1' synchronous condensers have already been awarded, which includes the supply of two smaller synchronous condenser units at each site to meet our specifications. Four 'Phase 2' synchronous condensers were identified to prepare the power system for the retirement of the remaining NSW coal generators (beyond Eraring Power Station), plus one additional to support the remediation of the South West Renewable Energy Zone (REZ).

This Report presents Transgrid's final assessment of material changes in circumstances (MCC) that have occurred since the publication of the PACR, including incorporation of feedback received during the consultation period for the draft MCC assessment. The assessment has led to a refinement of the preferred option identified in the PACR, undertaken in accordance with clause 5.16.4(z4B) of the National Electricity Rules (NER).

Transgrid provided a notification to the Australian Energy Regulator (AER) in April 2026, to advise that a reopening trigger specified in the PACR had been met, in addition to changes to two other key assumptions.¹⁶ Transgrid's notification to the AER included a set of proposed actions to address the MCC. In June 2026, the AER then determined the following actions were required:¹⁷

1. Undertake a streamlined cost benefit analysis, drawing on:
 - (a) the existing PACR analysis
 - (b) updated cost and timing information; and
 - (c) the most recent AEMO ISP-related inputs¹⁸ and outputs and AEMO's 2025 Transition Plan for System Security, where relevant.
2. Transgrid must publish a draft statement on its website by 24 June 2026 which:
 - (a) sets out:

¹⁶ [Meeting system strength requirements in NSW – Notification of Material Change in Circumstances Assessment](#), Transgrid, April 2026

¹⁷ [Material change in circumstances – Meeting system strength requirements in NSW – Determination](#), AER, June 2026

¹⁸ The most recent AEMO ISP-related inputs are from the 2026 ISP, which has been used for this MCC assessment.

- (i) a statement that the preferred option identified remains the preferred option, as well as any supporting information necessary to demonstrate that the preferred option identified remains the preferred option; or
 - (ii) a statement that the preferred option is no longer the preferred option and identifying the new preferred option, as well as any supporting information necessary to demonstrate that the preferred option is no longer the preferred option and the reasons the new preferred option is the preferred option;
 - (b) provides supporting information setting out the range of all potential solutions which could reasonably be expected to provide system strength, as well as reasons why any potential options were not considered credible or are considered to not form part of the preferred portfolio option;
 - (c) provides a description of each of the changes in circumstances, including the changed operation of synchronous generation, and its materiality to the analysis; and
 - (d) presents the updated cost benefit analysis developed under paragraph (1).
3. Transgrid must seek submissions from registered participants, AEMO and interested parties on the preferred option presented and the issues addressed in the draft statement. The period for submissions must be 1 month from the date Transgrid publishes the draft statement on its website.
 4. Transgrid must publish a final statement which sets out the matters required under paragraph (2), incorporates feedback from submissions and provides a summary of, and response to, submissions received during the consultation period. The final statement must be published on Transgrid's website within 1 month of the closing date for submissions, at the latest by 24 August 2026.

This MCC assessment includes the outcomes of the updated assessment and details changes made to the preferred option. Appendix D provides a compliance checklist listing the relevant sections for each requirement outlined by the AER.

Section 3 and Appendix E provide a summary of stakeholder feedback received during consultation on the draft MCC assessment, and how Transgrid has incorporated this feedback in the final MCC assessment.

1.2. Transgrid's system strength obligations

System strength is a fundamental service required for the secure operation of the power system. System strength is the ability of the power system to maintain and control the voltage waveform, both during steady state operation and following a disturbance. Insufficient system strength can lead to instability, incorrect operation of protection systems, curtailment of inverter-based resources (IBR) and increased risk of widespread outages.

As the System Strength Service Provider (SSSP) for NSW, Transgrid is responsible to deliver both minimum and efficient levels of system strength. These levels are defined in AEMO's Transition Plan for System Security.¹⁹

Transgrid's system strength requirements are split into two components, being to:

- maintain the minimum three phase fault level specified by AEMO for each system strength node in NSW – referred to as the minimum level; and

¹⁹ [Transition Plan for System Security](#), AEMO, 2025


- achieve stable voltage waveforms for the level and type of IBR and schedule 5.3a plant projected by AEMO – referred to as the efficient level.

A detailed explanation of the identified need for system strength and obligations is outlined in section 2 of the PACR.²⁰

1.3. Timeline of activities to date for managing system strength in NSW

Transgrid commenced activities to meet system strength requirements in NSW following introduction of the new system strength framework in 2021. A timeline of historical and selected forecast activities is shown in Figure 4.

Figure 4. Timeline of regulatory and procurement activities



In July 2025, the PACR concluded that the preferred option under the RIT-T was a portfolio of solutions, comprising ten synchronous condensers on Transgrid's transmission backbone, 5 GW of grid-forming BESS for the efficient level and re-dispatch of hydro, gas and coal generating units. This outcome was the result of extensive technical studies, stakeholder engagement and net economic benefit assessments across over 100 individual network and non-network solutions.

In August 2025, a dispute was raised regarding Transgrid's application of the RIT-T.²¹ In December 2025, the AER published a determination, based on the grounds of the dispute, that Transgrid was not required to amend its PACR.²²

Following the completion of the PACR, Transgrid has commenced delivery of network and non-network solutions within the preferred portfolio option. Specifically, the following activities have been undertaken:

²⁰ Transgrid, 2025, Meeting system strength requirements in NSW [PACR](#), page 22

²¹ [Notice of Dispute of Transgrid's RIT-T for Meeting system strength requirements in NSW](#), Centre for Independent Studies, August 2025

²² [Determination on RIT-T dispute – Meeting system strength requirements in NSW RIT-T](#), December 2025, AER

- Transgrid has awarded contracts for the first five synchronous condenser sites (labelled 'Phase 1' synchronous condensers). These are being procured under the direction of the NSW Energy minister as a Priority Network Infrastructure Project (PNIP);²³
- Transgrid has contracted with SnowyHydro's Tumut 3 for system security services via operation in synchronous condenser mode, to be made available to AEMO and used when required; and
- Transgrid has initiated a tender process for up to 2 GW of grid-forming BESS for efficient level system security services.

²³ Details of Priority Network Investment Projects and the NSW Government's direction can be found [here](#)

2. Nature of the material changes in circumstances

This section describes the MCC and changes to key assumptions that have been identified since publication of the PACR, and how they have been considered in this assessment.

2.1. MCC reopening trigger addressed in this assessment

Transgrid notified the AER on 29 April 2026 that a RIT-T reopening trigger identified in the PACR had been met, in line with Clause 5.16.4(z4)(2) of the NER. Specifically, that the expected “costs of synchronous condensers required for 2031/32 or after increase by significantly more than 30%”.²⁴

Transgrid’s assessment is that the expected costs for the deployment of the second five ‘Phase 2’ synchronous condensers are expected to meet this trigger threshold. This has been informed by the competitive procurement process for the accelerated ‘Phase 1’ synchronous condenser project, which was deemed by the AER to be the result of a genuine and appropriate procurement process under the NSW EII Act.²⁵ Further cost and supply chain pressures are forecast for ‘Phase 2’ synchronous condensers, due to a highly constrained market and impacts of the conflict in the Middle East. The combination of these drivers has been factored into the assessment in this Report.

2.1.1. Increase in synchronous condenser capital costs

In October 2025, Transgrid signed a contract with GE Vernova to supply the first order of ‘Phase 1’ synchronous condensers required at five Transgrid sites. Transgrid awarded contracts to Consolidated Power Projects (CPP) and UGL for civil, foundation and building enabling works in mid-2026.

In April 2026, Transgrid submitted a revenue proposal to the AER for its accelerated ‘Phase 1’ synchronous condensers project.²⁶ The total cost of the project is \$1.13 billion (in \$FY25), representing an average cost of \$225 million (\$FY25) per site.²⁷

The average estimated synchronous condenser cost presented in the PACR was \$160 million, in \$FY24 (or \$163 million in \$FY25) with actual costs estimated to be within -20% to +30% of the base capital cost estimate. ‘Phase 1’ synchronous condenser costs represent a 38% increase against costs estimated within the PACR and are the basis for the reopening trigger being met. This increase has been driven by the continued escalation of global demand and supply constraints for this equipment, as power systems worldwide transition away from fossil fuels to renewable energy. This cost includes synchronous condenser supply and all necessary site civil, foundation and building enabling works.

Transgrid expects that the cost to deliver each of the ‘Phase 2’ synchronous condensers will increase beyond the average cost of the accelerated ‘Phase 1’ synchronous condensers, due to ongoing market constraints and further supply chain impacts from the conflict in the Middle East. The expected average cost for ‘Phase 2’ synchronous condensers is \$324 million (\$FY25), based on a Class 4 estimate (-30%, +40%).

2.2. Other changes in key assumptions included in this assessment

Two other changes to key assumptions used to identify the preferred option in the PACR have occurred. These changes may also constitute an MCC under Clause 5.16.4(z4)(3) of the NER as they may affect the

²⁴ [Meeting system strength requirements in NSW PACR](#), Transgrid, July 2025, Page 110

²⁵ [System strength project 2026-31 revenue proposal](#), Transgrid, April 2026, Page 49

²⁶ [Transgrid System Strength Project \(hybrid\)](#), Transgrid, April 2026

²⁷ Note a figure of \$1.19 billion was provided in the revenue proposal based on a September 2026 dollar cost basis. All figures in this MCC Report are based on 30 June 2025 dollars.

preferred option identified in the PACR.²⁸ These changes have been considered in this MCC assessment, namely:

- (i) **Delivery timing of ‘Phase 2’ synchronous condensers:** the potential for material increases in the delivery timeline for Transgrid’s ‘Phase 2’ synchronous condensers, due to the time required to complete the regulatory process (including the dispute on Transgrid’s PACR, this MCC assessment, the risk of further MCC assessments being required and a contingent project application under the NER) and increasing lead times for available manufacturing slots (‘length of the queue’) for synchronous condensers due to tightening supply chains; and
- (ii) **Coal retirement dates:** changes to retirement dates and operational behaviour of NSW coal generation units, as forecast in AEMO’s 2026 ISP Step Change scenario and AEMO’s 2025 Transition Plan for System Security.

These changes in key assumptions are expected to affect the preferred portfolio set out in the PACR and therefore may constitute an MCC for the purposes of clause 5.16.4(z4).

The following sections describe the MCC key assumption changes since the PACR was published.

2.2.1. Timing of earliest synchronous condenser delivery

Estimated delivery timing for synchronous condensers is highly contingent on the time required for regulatory approvals, which then determines when manufacturing slots can be secured, in a context of sustained, heightened global demand for this equipment.

The delivery timeline for Transgrid’s ‘Phase 2’ synchronous condensers has shifted materially from the timing assumed in the PACR (a range between March 2029 and February 2030 for the first synchronous condenser) to the beginning of FY34 for the first synchronous condenser, on the condition that their commercial feasibility has been resolved. This is due to the time taken to resolve the dispute process on Transgrid’s PACR²⁹ and this MCC process, as well as tightening supply chains due to rising global demand which is leading to increased lead times to obtain manufacturing slots.

This MCC assessment also considers an alternative synchronous condenser timing, from the beginning of FY31. This reflects an accelerated timeframe where early access to manufacturing slots with a shorter lead time is possible. This timing is not currently considered feasible. Acceleration is expected to only be feasible if procurement commences prior to the AER’s approval of a contingent project application and if commercial feasibility can be confirmed.

More detail on synchronous condenser timing is provided in Section 4.1.

2.2.2. Changes to coal unit retirement dates and operational assumptions

The projected retirement timing of NSW coal-fired generators has changed under AEMO’s latest 2026 ISP Step Change scenario, compared with AEMO’s 2024 ISP, which informed Transgrid’s system strength PACR. The retirement of Vales Point units and Bayswater units were deferred until FY34. Guidance provided by the AER is that SSSPs should use AEMO’s latest Step Change scenario when applying the RIT-T.³⁰


²⁸ Under NER 5.16.4(z4)(3), these changes in assumptions may constitute an MCC where, in the reasonable opinion of Transgrid, they may mean that the preferred option identified in the PACR may no longer be the preferred option.

²⁹ Following the PACR publication, the AER received a notice of dispute on Transgrid’s system strength PACR in August 2025 and published its determination on the [dispute](#) in December 2025.

³⁰ [The Efficient Management of System Strength Framework AER Guidance Note](#), AER, December 2024, Page 30.

The changes in coal retirement dates under the 2026 ISP Step Change scenario are shown in Figure 5, in addition to the timing of retirement advised by the owners of NSW coal generators (i.e. 'Proponent Advised' dates).³¹

Figure 5. Comparison of NSW coal unit retirement trajectory forecasts



Coal generator units provide system strength as a byproduct of their operation. Due to the ongoing operation of coal generators in the energy market associated with deferred retirement dates compared with the 2024 ISP (underpinning the PACR modelling), the need for additional system strength is reduced, particularly between FY28 and FY30.

Transgrid's power system modelling indicates that the 'Phase 1' synchronous condensers, along with non-network contracts for system security services, will be sufficient to meet system strength needs until FY31 under the 2026 ISP Step Change scenario. From FY31, there will be six coal generator units remaining in NSW, at which time new sources of system strength will be required.

The 2026 ISP and AEMO's December 2025 Transition Plan for System Security also forecast changes to the operating behaviours of coal generators, with coal generating units behaving more flexibly, to better align with market prices. These changes and their effects on system strength are tabulated below.

Table 5. Changes to coal operating behaviour and the associated effect on system strength provision

Change in behaviour	Effect on system strength provision
Introduction of two-shifting	Two-shifting reduces a coal generating unit's participation in the market by reducing generation output to zero (and desynchronising from the grid) for short periods of time, e.g. off in the morning and on again for the evening peak. During these periods, a coal unit does not provide any system strength. Bayswater units have exhibited two-shifting behaviour in the market. ³²
Reduced minimum stable operating level (MSOL)	The MSOL for some NSW coal units has reduced since AEMO's 2024 ISP. This lowers the cost of coal unit 're-dispatch' (i.e. increased operating hours of a coal unit to meet system strength requirements).

³¹ As per AEMO's April 2026 Generating Unit Expected Closure Year file, which can be found [here](#).

³² [ASX & Media Release](#), AGL, 27 November 2025, AGL Bayswater Power Station site tour. "We can now selectively two-shift Bayswater units, by shutting down and restarting units between demand peaks to optimise margin.", p11.

Change in behaviour	Effect on system strength provision
Seasonal mothballing	AEMO's 2025 Transition Plan for System Security identified that some coal units in NSW may decommit from the market for months at a time (termed 'seasonal mothballing') as early as July 2028. ³³ This is more likely to occur during shoulder periods when electricity prices are typically lower. This would reduce the system strength provided as a byproduct of typical energy market operation. The lead time to ready a coal unit from this state to fill gaps in system strength can be prohibitively long.

AEMO has identified that ageing coal generators present an increasing risk of unavailability, as outlined in its 2025 Transition Plan for System Security, stating that “*statistically, failure rates increase as plants near the end of their planned operational life*”.³⁴

In the 2025 Thermal Audit, AEMO also stated that more flexible operating practices of coal units can accelerate equipment degradation by shifting the expected “*bathtub curve*” of failure rates forward and potentially introducing additional failure modes across the plant lifecycle.³⁵

Increased flexible operations, including those included in Table 5 above, may reduce the reliability of coal plants, compounding the risk to ageing assets. Decreased plant reliability impacts system strength availability and presents risks to power system security unless appropriately managed. To assess how changing coal behaviour may affect the preferred portfolio option, we have conducted a case study (see section 9.2) with reduced coal availability due to early coal retirements, unexpected failure or seasonal mothballing.

We have also examined additional coal unit retirement dates beyond Proponent Advised coal unit retirement dates. Discussion of this is provided in Section 8.3.

2.3. Other changes to assumptions which are not material to this assessment

2.3.1. Eraring Power Station extension

Eraring Power Station has announced it will defer its retirement date from August 2027 to April 2029.³⁶ The additional system strength associated with Eraring's continued operation is expected to reduce the need for re-dispatch of other synchronous machines over this period. Transgrid will assess the impact of this change through its contracting process with synchronous machines, to ensure a prudent and efficient outcome.

The delayed retirement date does not affect the outcome of this MCC assessment, as Eraring's deferred retirement date is still earlier than the earliest timing of 'Phase 2' synchronous condensers or grid-forming BESS for the minimum level.

2.3.2. Changes to Inverter-based resources (IBR) forecasts

In December 2025, AEMO published updated IBR forecasts in the 2025 Transition Plan for System Security, which sets Transgrid's efficient level requirements. These forecasts were derived from ongoing modelling being prepared for AEMO's 2026 ISP.

³³ [2025 Transition Plan for System Security](#), AEMO, Page 60

³⁴ [2025 Transition Plan for System Security](#), AEMO, Page 21

³⁵ [2025 Thermal audit](#), AEMO, November 2025, Page 13

³⁶ Origin extends Eraring Power Station operations to 2029, Origin, January 2026

Efficient level requirements are being addressed largely through non-network solutions (specifically grid-forming BESS), except for system strength needs within the South West REZ, which involves a combination of network and non-network solutions (see Section 5.3 for additional details).

For efficient level needs where non-network solutions formed part of the preferred portfolio, Transgrid will conduct a holistic assessment of non-network system strength needs in the contracting timeframe, to ensure prudence and efficiency. This includes assessment of Transgrid's connection pipeline to determine where the system strength need is arising.

3. Consultation on the Draft MCC Report

This Final MCC Report addresses feedback received during the consultation period for the Draft MCC Report. Four submissions were received over the four-week period; all submissions have been published on our website.

The parties who submitted are:

- Andritz Hydro – a supplier of synchronous condensers that participated in Transgrid's 'Phase 1' procurement process.
- Castle Group – a BESS proponent that is developing a portfolio of BESS in NSW, including a 1,000 MW / 4,000 MWh, four-hour BESS at Kemps Creek (with targeted commercial operation on 1 January 2030) as well as a second four-hour grid-forming BESS of up to 900 MW / 3,600 MWh at Regentville.
- Lake Lyell Hydro – a 385 MW / 8 hour pumped hydro energy storage joint venture project under development near Lithgow between EDF Power Solutions Australia and EnergyAustralia.
- Several members of Transgrid's Consumer Advisory Group – our expert consumer-focused advisory body that provides informed consumer insights on a range of key issues across the energy sector.³⁷

Across these submissions, four broad areas were raised for consideration, including:

- Support for the reassessment of the preferred portfolio, including the revision of the number of 'Phase 2' synchronous condensers from five to three.
- Providing additional information on emerging system strength solutions, including the Lake Lyell Pumped Hydro facility and a portfolio of grid-forming BESS projects.
- The importance of preserving flexibility to pivot from synchronous condensers to alternative solutions (e.g. new synchronous machines with synchronous condenser capability and grid-forming BESS once proven technically feasible for the minimum level of system strength), if in the interest of consumers.
- Further clarity of requirements for grid-forming BESS to demonstrate technical feasibility for the minimum level.

We have taken all feedback received through submissions and stakeholder feedback sessions into account and have incorporated key considerations into the Final MCC Report. These include more detailed explanations of the decision-making trade-off associated with long-lead time system strength solutions, how Transgrid proposes to retain flexibility to explore alternative solutions, and indicative timeframes for procurement of 'core' non-network solutions. In addition, we have taken the opportunity to directly respond to the proposals received from Lake Lyell Hydro and the Castle Group.

A full summary of all matters raised as part of consultation on the MCC Draft Report is provided and responded to in Appendix E.

Transgrid thanks those involved in the consultation process for this MCC assessment, the RIT-T process and ongoing engagement on managing system strength in NSW.

³⁷ Members of Transgrid's Consumer Advisory Group who have lodged this submission are Louise Benjamin, Gavin Dufty and Mary Karras.

4. Individual solutions assessed

This section summarises the individual system strength solutions available in the assessment which are combined to form portfolio options that meet the need. The following individual solutions have been considered, with their technical and commercial feasibility summarised in Table 6:

- synchronous condensers;
- grid-forming BESS for the minimum level; and
- 're-dispatch' (increase in operating hours) of synchronous machines (hydro, gas, coal).

Table 6. Comparison of technical and commercial feasibility and timing of available options

Technology	Feasibility	Timing
'Phase 2' synchronous condensers	Technically feasible, however, not currently commercially feasible. Current cost of finance is higher than the compensation available under the regulatory regime.	If commercially feasible, synchronous condensers could be operational in FY34, under an assumed delivery timing which follows the standard NER process. An accelerated process could deliver the project in FY31, if commercial feasibility can be resolved.
Grid-forming BESS for the minimum level of system strength	Grid-forming BESS are not currently considered technically feasible to provide protection-quality levels of fault current. ³⁸ However, independent advice from Aurecon anticipates that grid-forming BESS may become feasible to meet minimum level requirements from FY33.	Noting technical feasibility has not been confirmed, grid-forming BESS for the minimum level have been included in the assessment from FY33, but only to the extent that there are sufficient fallback solutions to meet the system strength need if grid-forming BESS do not perform as anticipated.
Re-dispatch of synchronous machines (hydro, gas) ³⁹	Technically and commercially feasible, up to a defined limit for gas generators, based on pipeline and gas supply constraints.	Available immediately in all portfolio options for existing plant or at in-service date for committed and anticipated generators.

Another potential solution for system strength is new synchronous plant with synchronous condenser capability or modifications to existing plant to enable synchronous condenser mode. Synchronous condenser mode modifications are bespoke and are not always technically feasible based on the design or age of the plant; technical feasibility must be demonstrated on a plant-by-plant basis. However, no technically and commercially feasible options have materialised since the system strength PACR.

³⁸ This is based on AEMO's public position (AEMO, May 2024, Update to the 2023 Electricity Statement of Opportunities and more recently, AEMO's 2025 Transition plan for system security, December 2025, Page 135) and independent advice from Aurecon to support Transgrid's system strength PACR (Advice on maturity of grid-forming inverter solutions for system strength, Aurecon, March 2024)

³⁹ Transgrid defines 're-dispatch' as an increase in the operating hours of synchronous generators to provide system strength, in addition to their typical energy market operations.

4.1. Synchronous condensers

Synchronous condensers are large rotating machines that help manage voltage, inject synchronous fault current and improve the stability of the power system.

The PACR preferred option included network synchronous condensers at ten Transgrid substations. Synchronous condensers for the first five sites ('Phase 1') have been awarded to GE Vernova, who will deploy two smaller synchronous condenser units at each site to meet Transgrid's specifications. Since 'Phase 1' synchronous condensers are committed assets, they are included in the base case of this analysis. The additional synchronous condensers under assessment via this MCC are labelled 'Phase 2'.

4.1.1. Drivers for cost and delivery timing assumption changes for synchronous condensers

Since the PACR, Transgrid has progressed procurement activities for 'Phase 1' synchronous condensers, and this process was used to inform the assumptions used in this MCC assessment for the remaining 'Phase 2' synchronous condensers. This section describes the key drivers affecting the cost and delivery timing assumptions of 'Phase 2' synchronous condensers, which include:

- extended regulatory processes;
- increased global demand for synchronous condensers; and
- tightening supply chains for synchronous condensers and design and construction services, in particular due to geopolitical factors.

Extended regulatory processes

The delivery timing for 'Phase 2' synchronous condensers has been revised, in part, due to additional regulatory processes required to be followed to enable the project to progress into the delivery stage. Specifically, the synchronous condenser timing assumed in the PACR did not include time to complete:

- the dispute process on Transgrid's system strength PACR.⁴⁰ The dispute process was initiated in August 2025 and was resolved in December 2025, when the AER determined that the PACR did not need to be amended; and
- this MCC assessment. The MCC assessment commenced in December 2025 and is now completed with the publishing of this final MCC Report in August 2026.

Transgrid is obligated to monitor and assess further MCCs which may occur prior to submitting a regulatory proposal for a contingent project application under the NER. The potential for future MCCs creates uncertainty on the project scope and may delay the timing of contract award for the manufacture of synchronous condensers.

Due to increasing global demand, the queue for manufacturing slots is projected to increase over time. This means that delays to commencing procurement and regulatory approval processes create a risk of extended delivery lead time for this equipment, even if the time to manufacture the synchronous condensers does not change. Delays in commencing procurement would likely require a re-tendering for future synchronous condensers.

⁴⁰ Following the PACR publication, the AER received a notice of dispute on Transgrid's system strength PACR in August 2025 and published its determination on the [dispute](#) in December 2025.

Increased global demand for synchronous condensers

Demand for synchronous condensers is increasing as power systems around the world transition from fossil fuels to renewables. The equipment is highly specialised, with a limited number of original equipment manufacturers globally. This can make securing manufacturing slots highly competitive. The table below shows recent international and domestic demand for this technology, noting that this list is not exhaustive.

Table 7. A sample of international and domestic demand for synchronous condensers

Location	Synchronous condensers	Timing of award
International demand for synchronous condensers		
United Kingdom ⁴¹	4	April 2022
New York ⁴²	6	June 2024
Chile ⁴³	4	July 2024
Italy ⁴⁴	5	February 2025
Texas ⁴⁵	2	May 2025
Ireland ⁴⁶	4	October 2025
Saudi Arabia ⁴⁷	Nine sites	October 2025
Brazil ⁴⁸	6	January 2026
Domestic demand for synchronous condensers		
New South Wales – Central West Orana REZ ⁴⁹	7	May 2025
Queensland ^{50,51}	9	Four procured, with the remaining in planning
Victoria ⁵²	5	Upcoming procurement

Domestically, all eastern states completed their system strength RIT-Ts at similar times, with the outcomes for Queensland and Victoria also identifying synchronous condensers in their preferred portfolios. This may create further localised pressure on synchronous condenser delivery and installation.

Tightening supply chains for both synchronous condenser and design and construction services

Recent and ongoing geopolitical events continue to impact global supply chains. The conflicts in Ukraine, and the Middle East, are increasing costs across all infrastructure projects, as prices for inputs across the

⁴¹ [Quinbrook awarded four new contracts in Phase 2 of National Grid's pathfinder](#), Quinbrook, April 2022

⁴² [GE Vernova to build two turn-key synchronous condenser sites designed to improve grid stability in upstate New York, GE Vernova](#), June 2024

⁴³ [GE Vernova to supply synchronous condensers equipment to help improve grid stability in Northern Chile](#), GE Vernova, July 2024

⁴⁴ [Ansaldo Energia develops the grid with 5 new synchronous condensers](#), Ansaldo energy, February 2025

⁴⁵ [Andritz to build synchronous condenser facilities to strengthen grid stability in Texas](#), Andritz, May 2025

⁴⁶ [Renewable energy integration: Andritz to supply four synchronous condensers for Statkraft project in Ireland and Northern Ireland](#), Andritz, October 2025

⁴⁷ [SEC awards synchronous condensers projects across Saudi Arabia](#), Saudi Golf Projects, October 2025

⁴⁸ [Andritz to supply six synchronous condensers to stabilise Brazil's power grid](#), Andritz, January 2026

⁴⁹ [Siemens Energy partners with ACERZ on NSW Renewable Energy Zone](#), Siemens Energy, May 2025

⁵⁰ [Powerlink awards procurement for four synchronous condensers to Hitachi Energy](#), Powerlink, April 2026

⁵¹ [Meeting system strength requirements in Queensland PACR](#), Powerlink, June 2025

⁵² [Meeting system strength requirements in Victoria PACR](#), AEMO Victoria Planning, August 2025

supply chain are impacted.⁵³ These pressures also have flow-on impacts on domestic labour, particularly in the energy sector.⁵⁴ These effects are expected to extend beyond the conflict itself.

These supply chain impacts have driven further increases in the cost estimate for 'Phase 2' synchronous condensers, beyond costs established through the accelerated 'Phase 1' procurement process. Ongoing geopolitical uncertainty, and associated supply chain impacts, have resulted in Transgrid widening the cost accuracy range for 'Phase 2' synchronous condensers to -30% to +40%, compared to -20% to +30% for the PACR.

4.1.2. Commercial feasibility of 'Phase 2' synchronous condensers

Currently, the actual cost of funding projects is higher than that provided by the AER's rate of return instrument (RORI). This creates an investability issue with no clear solution under the NER. We will continue to engage with the AER to assess our options, including any flexibility that the AER may have when making a contingent project determination. Transgrid has highlighted this issue on several occasions and most recently during the AER's draft RORI consultation process.⁵⁵

In past large projects, Transgrid has worked with the AER and various government agencies to close the gap with additional support or alternate approval pathways, successfully reaching financial close. Transgrid plans to take the same approach for capital investments contemplated in this MCC.

4.1.3. Basis for assessing two synchronous condenser delivery timings

The timing of 'Phase 2' synchronous condensers is dependent on multiple factors, explained in Section 4.1.1, which creates uncertainty for the delivery timing to be assumed for this MCC assessment. As such, we have assessed two timings for 'Phase 2' synchronous condensers in this MCC assessment, similar to the approach taken in the PACR. The timings and key assumptions are listed in Table 8.

Table 8. Synchronous condenser delivery timing

Description	Timing	Key assumptions
Assumed timing	July 2033 (FY34)	- Longer regulatory approval processes (including potential for additional MCCs which require re-testing of project need and scope), delaying contract award. - Extended synchronous condenser procurement lead times, due to growing international demand and tighter supply chains during extended regulatory and procurement processes. - Assumes commercial feasibility can be resolved.
Accelerated timing	July 2030 (FY31)	- Transgrid completes regulatory and procurement processes and award contracts before lead times for available manufacturing slots increase. - Lead time based on current Original Equipment Manufacturer (OEM) estimate. - Note that this timing is not currently considered feasible. Acceleration is expected to only be feasible if procurement commences prior to the AER's approval of a contingent project application. - Assumes commercial feasibility can be resolved.

⁵³ 2025 Electricity Network Options Report, AEMO, August 2025, Page 6

⁵⁴ 2025 Infrastructure Market Capacity Report, Infrastructure Australia, November 2025

⁵⁵ Transgrid, 31 July 2026, Submission on draft 2026 RORI, <https://www.aer.gov.au/documents/transgrid-submission-draft-2026-rori-31-july-2026>

While the delivery timing of FY34 has been modelled under the assumed timing, earlier delivery may be possible if contract award can occur faster than anticipated.

4.1.4. Revised assumptions for 'Phase 2' synchronous condensers

Changes to synchronous condenser cost assumptions for this MCC assessment compared to the PACR are presented in Table 9, reflecting latest information based on 'Phase 1' procurement and detailed feasibility studies for 'Phase 2' sites. Underlying drivers of cost increases are explained in sections 4.1.1 and 4.1.2, above.

Table 9. Summary of changes to synchronous condenser costs

Regulatory stage	Average cost per site & cost estimation range (\$FY25)	Description
PACR, for 'Phase 1' and 2 synchronous condensers	\$163 million ⁵⁶ (-20%, +30%)	PACR estimates were based on non-binding market sounding, completed in March 2025.
Revenue Proposal, for accelerated 'Phase 1' synchronous condensers ⁵⁷	\$225 million ⁵⁸	- Includes contract costs with GE Vernova for the supply of synchronous condensers to each site as well as with CPP and UGL for civil, foundation and building enabling works. Each of these contracts were the result of competitive procurement processes that were deemed by the AER to be genuine and appropriate procurement processes, under the NSW EII Act.⁵⁹ - The procurement process allowed different synchronous condensers sizes or combinations of units which could provide fault current within a target range. This allowed Transgrid to receive the best price by enabling a broader range of products to be considered.
MCC assessment, for 'Phase 2' synchronous condensersden	\$324 million (-30%, +40%)	- Updated costs for the MCC assessment are informed by contract costs for 'Phase 1' synchronous condensers, market escalation as well as supply chain impacts of the conflict in the Middle East. - Inclusion of a single spare transformer across the fleet of 'Phase 2' synchronous condensers in this MCC assessment, to manage the high-impact low-probability risk of a transformer failure at a 'Phase 2' synchronous condenser location.

⁵⁶ The average cost presented in the PACR was \$160 million, in \$FY24, with actual costs estimated to be within -20% to +30% of the base capital cost estimate. This cost has been escalated by CPI to enable a comparison in \$FY25.

⁵⁷ [Transgrid System Strength Project \(hybrid\)](#), Transgrid, April 2026

⁵⁸ The revenue proposal stated a cost of \$1.19 billion for five sites, therefore averaging \$238 million per site, based on a dollar cost basis of September 2026. All costs for this MCC assessment are shown in 30 June 2025 dollars. Transgrid [System Strength Project \(hybrid\)](#), Transgrid, April 2026

⁵⁹ [Transgrid System Strength Project \(hybrid\)](#), Transgrid, April 2026, Page 49

Changes to other assumptions for ‘Phase 2’ synchronous condensers are presented in Table 10, including fault current contribution, earliest delivery timing and preferred locations.

Table 10. Summary of changes to synchronous condenser assumptions

Assumption	PACR	MCC assessment	Reason for change
Fault current contribution per site ⁶⁰	1,050 MVA	927 MVA	Based on contribution of awarded ‘Phase 1’ synchronous condensers.
Timing	FY30	FY31 and FY34 (two timings considered)	See Table 8 above.
Preferred sites for ‘Phase 2’ synchronous condensers in order of preference			
Site 1	Dinawan	Dinawan	Completion of detailed feasibility studies for Eraring, Liddell, Munmorah and Waratah West (in addition to previously completed feasibility studies for a second synchronous condenser at Newcastle and Kemps Creek).
Site 2	Kemps Creek	Munmorah	
Site 3	Newcastle	Newcastle	
Site 4	Eraring	Waratah West	
Site 5	Liddell	Kemps Creek	

The Dinawan synchronous condenser location is for remediation of inverter-based generation associated with the South West REZ. The remaining synchronous condensers are in the Sydney/Newcastle region, to replace system strength that was previously provided by coal generating units in NSW.

In the PACR, we identified that it may be necessary for Transgrid to re-evaluate and change the location of a network synchronous condenser to a different substation in the same region. This may occur if site constraints, unexpected costs or complexities are identified during the detailed design and procurement phases. This has occurred since the PACR, with Munmorah becoming the preferred site in the Sydney/Newcastle region while Eraring and Liddell have been removed. This change was driven by site suitability with Munmorah having a lower cost estimate than the alternative sites.

The benefits of synchronous condensers at Transgrid substations within the Sydney West, Newcastle or Hunter Valley regions are considered broadly interchangeable and would not materially affect the estimated net market benefits.

4.2. Grid-forming BESS contribution towards minimum level requirements

Grid-forming BESS is considered mature for providing efficient level system security services. Transgrid’s system strength PACR identified 5 GW of grid-forming BESS for the efficient level as part of the preferred portfolio of solutions by the early 2030s. Transgrid has initiated a tender for up to 2 GW of grid-forming BESS for the efficient level need.⁶¹ Considering the ability of grid-forming BESS to ‘value-stack’ system security services with its other functions, including energy shifting and frequency control, its provision of efficient level services is expected to come at a low marginal cost.

However, grid-forming BESS are not currently considered technically feasible for contributing towards the minimum level of system strength, as their capability to provide protection quality fault current has not yet

⁶⁰ Fault current based on nominal unsaturated sub-transient reactance.

⁶¹ Transgrid, April 2026, [Media release](#), Critical NSW grid stabilisation plans advance to final stages


been demonstrated. This was stated⁶² by AEMO in 2024 and re-confirmed in the 2025 Transition Plan for System Security, with AEMO noting that the “*provision of protection quality fault current remains a key limitation of GFM*”.⁶³ The key limitations of grid-forming BESS for protection quality fault current are detailed in a report commissioned by AEMO.⁶⁴ The Etik Energy report states “*grid-forming inverters offer improved stability and impedance control but still face limitations in fault current magnitude and consistency*”.⁶⁵

This creates challenges for the reliable operation of protection systems, because protection equipment has been designed and configured based on the fault response of synchronous machines and the fault current response of grid-forming BESS is inherently different to synchronous machines. This is a priority action listed in AEMO’s Engineering Roadmap⁶⁶ and is a subject of an AEMO Type 2 trial.⁶⁷ Transgrid has commenced engagement with industry bodies to progress further research and trials of this technology.

4.2.1. Projected timing of technically feasible grid-forming BESS contribution towards minimum level requirements

Transgrid’s view on the steps anticipated to be required to demonstrate how grid-forming BESS can provide protection quality fault current is shown in Figure 6. Note these steps are indicative only and will be further informed by industry including the status of AEMO’s Type 2 trials.

Figure 6. Indicative steps to prove technical feasibility of grid-forming BESS for the minimum level



An independent assessment completed by Aurecon during Transgrid’s system strength RIT-T estimated grid-forming BESS could be technically feasible from FY33.⁶⁸ A similar independent report commissioned by AEMO re-confirmed the limitations of the technology for providing protection-quality fault current.⁶⁹ This timing assumption was applied in the PACR, with grid-forming BESS available to be selected by the model from FY33. In the PACR, solutions for the minimum level were required well before FY33, given the earlier

⁶² AEMO, May 2024, Update to the 2023 Electricity Statement of Opportunities

⁶³ 2025 Transition Plan for System Security, AEMO, December 2025, Page 135

⁶⁴ [Grid-Forming and Grid-Following Inverter Fault Current Contribution](#), Etik Energy, November 2025

⁶⁵ [Grid-Forming and Grid-Following Inverter Fault Current Contribution](#), Etik Energy, November 2025

⁶⁶ Engineering roadmap FY2026 priority actions report, AEMO, July 2025, Page 40

⁶⁷ <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/nem-forecasting-and-planning/transition-planning/transitional-services---type-2-services/grid-forming-inverter-protection-quality-fault-current-trial>

⁶⁸ Advice on the maturity of grid forming inverter solutions for system strength, Aurecon, March 2024

⁶⁹ [Grid-forming and grid-following fault current contribution](#), Etik Energy, November 2025

coal retirements, meaning that no grid-forming BESS for the minimum level were selected in the preferred portfolio.

Based on the time required to undertake the steps outlined above, and with consideration of industry updates including the status of AEMO's Type 2 trials, Transgrid does not consider any change to this FY33 time estimate is justified at this stage. There is still considerable uncertainty of the scope required to enable the technology, as outlined below:

- The availability and maturity of Electromagnetic Transient (EMT) models for protection relays, as EMT modelling on protection relays has not historically been required.
- The extent of potential change required to both protection relay and inverter capacities and operational logic.
- Time required and regulatory pathway to enable changes to protection schemes, if required.
- Availability and maturity of grid-forming BESS projects in the Sydney West region.

Transgrid has commenced work on the steps outlined above, will continue to engage with industry and monitor updates of this technology. Transgrid recognises other network service providers, independent research bodies and original equipment manufacturers are also progressing development of this technology, such as the recently published report by the CSIRO investigating grid-forming inverter response impacts upon protection schemes using different tuning parameters.⁷⁰

Although not currently considered a technically feasible solution, due to its strong potential to form part of the preferred portfolio option, Transgrid has included it as a solution for consideration in this assessment from FY33, rather than excluding it altogether. To manage the risk posed to system security associated with the uncertainty of when, or if, grid-forming BESS will provide protection quality fault current, Transgrid will only rely on this solution to the extent that there are sufficient alternative fallback solutions available (i.e. gas and hydro re-dispatch). This is discussed further in Section 6.1.3.

4.2.2. Location of grid-forming BESS projects

During PACR and subsequent power systems modelling, Transgrid has identified the largest minimum-level system strength needs to be surrounding the Sydney West, and then Newcastle, nodes. Requirements at other nodes are expected to be met by 'Phase 1' synchronous condensers and other existing/committed sources of system strength.

For this MCC assessment, the fault level contribution of theoretical grid-forming BESS from different locations on the 330 kV network within the Sydney West region has been calculated using power system modelling. A location 'de-rating' was then applied to capture the diminishing contribution of solutions located further from the system strength node, as it is unlikely a solution will connect directly to the Sydney West node. Only potential projects on the 330 kV or 500 kV networks were included in the assessment, as the relatively high impedance on lower-voltage networks results in materially lower, and in some cases negligible, system strength contribution, making them inefficient solutions for the purposes of this assessment.

4.2.3. Costs applied to grid-forming BESS solutions

BESS included under the 2026 ISP Step Change scenario are modelled in this MCC assessment to have an incremental capital cost of only 5% of the total project cost, to reflect the potential uplift required to enable protection quality fault current capability. The underlying capital cost and operating costs of the projects themselves are not included in the assessment, as these costs are already assumed to be incurred in the

⁷⁰ [Implementation of Australia's Global Power System Transformation \(Stage 5\)](#), CSIRO, August 2026

base case given the projects are forecast to enter the market under the 2026 ISP Step Change scenario. This is consistent with the approach adopted in the PACR.

4.3. Re-dispatch of synchronous generators

Transgrid defines ‘re-dispatch’ as an increase in the operating hours of synchronous generators to provide system strength, in addition to their typical energy market operations.

4.3.1. Hydro

Hydro units provide system strength as a byproduct of their operation in either generating or pumping mode (where applicable). Some hydro units in NSW also have the capability to operate in ‘synchronous condenser mode’, where the turbine is de-watered, but remains synchronised to provide system strength without generating electricity. In this mode, the unit does not use water or require intervention in the electricity market beyond auxiliary power demand. This technology is well-suited to sustained operation. Transgrid has already contracted with SnowyHydro’s Tumut 3 units (which have synchronous condenser mode) for the provision of system strength.

This MCC assessment includes existing, committed and anticipated hydro units in NSW, similar to the PACR approach. As hydro re-dispatch is expected to be predominantly in synchronous condenser mode, the modelled cost is based solely on the additional maintenance costs from increased operation. There is no additional fuel usage or emissions production, so there are no associated costs. This is consistent with the PACR and RIT-T guidelines, where costs represent the underlying economic cost, rather than the expected cost to contract with the service provider.

4.3.2. Gas generators

Gas units are also assessed to be available for re-dispatch, up to a defined limit. There are no existing gas units in NSW with the capability for synchronous condenser mode, so this solution requires units to generate electricity to provide system strength, typically at a unit’s minimum stable operating level. The cost of gas re-dispatch included in the MCC assessment is dependent upon the fuel price, additional maintenance requirements and emissions production associated with generation.

Gas re-dispatch is not well-suited to sustained operation for system strength, due to pipeline and gas supply constraints limiting availability. Transgrid has developed two gas constraints for this analysis to reflect these considerations. These constraints are based on AEMO’s assessment of gas supply via its latest Gas Statement of Opportunities (GSOO),⁷¹ released in March 2026, as well as from technical advice provided by GHD to support Transgrid’s PACR. AEMO was consulted during the development of the gas constraints used in this MCC assessment. The two gas constraints are:

- limiting coincident gas re-dispatch for system strength at any point in time, to reflect pipeline limitations on the Sydney–Newcastle line. This pipeline supplies gas to the bulk of the gas units in NSW which provide a material system strength contribution to the Sydney West and Newcastle regions; and
- limiting total annual gas re-dispatch based on a percentage of annual typical energy market dispatch, to reflect gas supply limitations. This constraint becomes more stringent from FY33 as southern production declines.

⁷¹ 2026 Gas Statement of Opportunities, AEMO, March 2026

When gas re-dispatch exceeds the gas constraints in the model, it is considered a risk of a system strength gap and is quantified as involuntary load curtailment in the MCC assessment. Additional details of these constraints are provided in Appendix B, including the results when the gas constraints are not included.

The PACR included a pipeline constraint on the Sydney-Newcastle pipeline, which limits coincident gas re-dispatch for units served by this pipeline. The PACR did not implement a total annual gas constraint as it was not expected to affect the ranking of portfolio options. This was because only the lowest-ranking option had a material amount of gas re-dispatch, and including the constraint would have lowered its net market benefits further. For this MCC assessment, the gas constraints are expected to affect the ranking of portfolio options, which is why they have been included.

4.3.3. Coal generators

Coal unit re-dispatch was not included in this MCC assessment. Coal generator unit availability is highly uncertain given reliability, fuel supply, seasonal mothballing and potential early retirements. In addition, under the Improving Security Framework rule, AEMO is prevented from enabling a contract for security purposes more than 12 hours ahead of the trading interval; this potentially rules out coal re-dispatch from cold start.⁷²

Finally, the modelling horizon commences in FY31 in this analysis and there is limited coal availability beyond FY34 after the retirements of Eraring, Vales Point and Bayswater units (unlike the PACR where the modelling horizon commenced in FY26). As such, including coal re-dispatch was not considered in this analysis.

Transgrid will procure system security services from synchronous machines in the contracting timeframe based on latest information and unit availability from all technologies.

⁷² AEMC, March 2024, [Improving security frameworks for the energy transition rule change](#)

5. Modelling approach and assumptions

In Transgrid's MCC notice to the AER, we proposed a streamlined assessment rather than a re-application of the RIT-T. This recommendation was supported by the AER,⁷³ with consideration given to the likely high cost to the energy market, and ultimately consumers, that would result from the delay caused by the re-application of the RIT-T.

This section describes Transgrid's approach to the MCC assessment, including the scenarios modelled, characterisation of the base case and market benefit classes quantified.

5.1. Coal unit retirement dates


This MCC assessment considers a range of coal generator retirement dates, noting the uncertainty between and divergence of coal generator retirement dates projected under AEMO's 2026 ISP Step Change scenario, and the date currently advised by the owners of the coal generating plant ('Proponent Advised' dates). Transgrid has tested this range of coal retirement dates to provide robustness to the analysis and to mitigate the need for further MCC assessments, if subsequent ISPs were to indicate delayed retirement schedules. Transgrid has assessed two coal retirement schedules, as per Table 11.

Table 11. Coal generator retirement scenarios modelled in this MCC assessment

Scenario	Description
2026 ISP Step Change	Coal retirement dates are taken as an output of AEMO's 2026 ISP Step Change scenario. This represents the earliest coal unit retirement timing in this assessment.
Proponent Advised coal unit retirement dates	Coal retirement dates based on currently advised timing from proponents, as published by AEMO. ⁷⁴

The two coal generator unit retirement schedules modelled for this MCC assessment are shown in the graph below, along with the coal generator retirement schedule that underpinned the PACR analysis (2024 ISP).

Figure 7. Coal generator retirement scenarios considered in this assessment



⁷³ [Material change in circumstances – Meeting system strength requirements in NSW – Determination](#), AER, June 2026

⁷⁴ [Generating Unit Expected Closure Year – Apr 2026](#), AEMO, April 2026

As shown in Figure 7, the two coal generator retirement schedules used in this MCC assessment diverge between FY30 and FY33, before converging in FY34 and then diverging again from FY36. During these periods, the provision of system strength associated with typical market dispatch of coal generators will differ. Under the Proponent Advised coal generator retirement dates, where coal units remain in the market for longer, there will be increased operation of coal units in the energy market and therefore higher system strength provision. Modelling both coal generator retirement scenarios enables us to understand if extensions to coal unit retirement dates out to Proponent Advised retirement dates are material to the ranking of portfolio options.

For each coal generator retirement schedule, Transgrid has assessed the preferred portfolio under both the accelerated (FY31) and assumed timing (FY34) of synchronous condenser deployment (with no other difference in assumptions).

We also assessed the implications of coal unit retirement dates beyond the Proponent Advised coal unit retirement scenarios. These are discussed in Section 8.3.

5.2. Treatment of New England Renewable Energy Zone


The system strength PACR identified that seven synchronous condensers in the New England REZ are required to remediate the REZ as part of the preferred portfolio option, in addition to the ten synchronous condensers on Transgrid's transmission backbone. These solutions were separately itemised in the PACR, as Transgrid stated that EnergyCo may adopt an approach outside of the NER framework, where central system strength remediation is the responsibility of a third-party network operator (rather than Transgrid as the SSSP for NSW). EnergyCo is now leading the design of the system strength solution for the New England REZ. As such, Transgrid has excluded from this MCC assessment the identification of the portfolio of system strength solutions required for the New England REZ (and for Central West Orana REZ).

EnergyCo is exploring an approach for New England REZ where proponents largely self-remediate their system strength impact, either behind the connection point or 'in front of the meter'.⁷⁵ This would likely result in system strength remediation for the REZ being largely provided by grid-forming BESS. Transgrid is progressing joint planning with EnergyCo, including EMT studies, to support EnergyCo in confirming the efficient level requirement and the preferred system strength solutions for the REZ.

Based on experience from Transgrid's EMT studies completed for the PACR, we expect a grid-forming BESS solution will be capable of meeting the efficient level requirement for the level of IBR forecast under the 2026 Final ISP. However, synchronous condensers may be required based on the IBR forecast under the Infrastructure Investment Objectives report (IIO, used by EnergyCo) to complement the grid-forming BESS solution given the scale of renewables within the REZ (~10 GW).

⁷⁵ EnergyCo, August 2025, [New England Renewable Energy Zone Generation and Storage Consultation Paper](#)

Figure 8. Comparison of New England REZ IBR forecast under the ISP and the IIO



The flow of system strength from these potential New England REZ synchronous condensers could affect the ranking of portfolio options for Transgrid's transmission backbone. These synchronous condensers are not expected to be required for the level of IBR forecast in the 2026 Final ISP, so these possible synchronous condensers have not been considered in the core MCC assessment.

However, while the IIO's higher IBR forecast is not in the 2026 Final ISP, EnergyCo is actively planning its delivery. As such, Transgrid has undertaken a sensitivity in this MCC assessment where two synchronous condensers are required within New England REZ (even if a grid-forming BESS dominated solution is pursued).

This sensitivity has been developed to test whether the fault current contribution from these New England REZ synchronous condensers, which would propagate into the broader NSW network, would change the composition of the preferred portfolio option. The sensitivity is helpful to manage the risk of a future MCC for a change to the system strength solution for New England REZ. The results to this sensitivity are outlined in Section 10.1.

5.3. Treatment of the Dinawan synchronous condenser

The South West REZ is being developed by EnergyCo, and Transgrid has maintained responsibility for system strength remediation as the SSSP for NSW. The South West REZ is expected to host 3.56 GW of IBR at or near Dinawan substation by the early 2030s.⁷⁶

As identified in the PACR, Dinawan is electrically distant from the nearest system strength nodes, which reduced the effectiveness of the available fault level methodology. Transgrid opted to complete a separate out-of-model assessment using EMT studies to assess solutions to meet the efficient level need and identify the cost impacts of any constraints on access rights projects in the REZ. The assessment for the PACR identified one synchronous condenser at Dinawan was required within the preferred portfolio.

The need and analysis remain unchanged from the PACR (including when considering latest IBR forecasts from AEMO's 2026 ISP), but the same market benefits methodology has been applied for this assessment

⁷⁶ [South West Renewable Energy Zone](#), EnergyCo

given the revised synchronous condenser timing. Transgrid is engaged in joint planning with EnergyCo for the delivery of the South West REZ.

Further details can be found in Appendix J of the PACR.⁷⁷

5.4. Representation of the base case

The purpose of the base case is to provide a baseline or ‘do nothing’ counterfactual against which different portfolio options and sensitivities can be compared. A ‘do nothing’ scenario would mean that Transgrid does not procure any additional system strength solutions to meet the minimum level need beyond what is already anticipated or committed to be deployed. This scenario would ultimately incur significant system strength violations and unserved energy for consumers. Net market benefits of each portfolio option are assessed against a ‘do nothing’ base case (or counterfactual scenario), in line with RIT-T requirements.

Over time, system strength gaps would be expected to occur as coal units increasingly decommit and retire. In real-time, AEMO would seek to close or reduce the impact of system strength gaps through recalling planned outages of transmission assets and generators or constraining output from IBR, with customer load shedding ultimately occurring.

Transgrid has used a modelling horizon from FY31 to FY45 for this assessment. Years before FY31 are not relevant to this assessment as they are before the earliest timing of new system strength solutions considered in this analysis. The system strength need is also lower before FY31, as under both coal retirement scenarios there are at least seven coal units in NSW, as well as Transgrid’s ‘Phase 1’ synchronous condensers. Transgrid will continue to refine the optimal portfolio from the PACR in the contracting timeframe using non-network solutions. The year FY45 was selected for consistency to the PACR.

Each coal unit retirement scenario has its own base case and forms a separate net market benefits assessment. The net market benefits between the two scenarios should not be compared, however the ranking of the portfolio options can be compared.

The table below summarises what is and is not included in the base case.

Table 12. Description of the base case

Treatment in base case	Components
Included	- Transgrid’s ‘Phase 1’ synchronous condensers - ACERES synchronous condensers for Central West Orana REZ - Synchronous condensers deployed as part of Project EnergyConnect - Re-dispatch of existing, committed and anticipated synchronous machines (via directions in lieu of non-network contracts with Transgrid) - Transmission augmentations included in the 2026 ISP Optimal Development Path
Excluded	‘Phase 2’ synchronous condensers - Grid-forming BESS contributions to the minimum level

⁷⁷ [Meeting system strength requirements in NSW](#), Transgrid, July 2025, Appendix J

5.5. Net market benefit assessment

Each identified portfolio option is assessed through a cost-benefit analysis against the base case, with the differences in each market benefit class calculated for each scenario, consistent with the PACR and RIT-T guidelines. The portfolio option which maximises net market benefits becomes the preferred option. This assessment is provided in the accompanying workbook.

5.5.1. Types of market benefits

Market benefits are calculated by comparing the 'state of the world' in the base case, where no action to meet the need is taken, with the 'state of the world' with each of the portfolio options in place, consistent with the RIT-T guidelines.⁷⁸

The market benefit classes that have been modelled for this MCC assessment are:

- changes in fuel consumption in the NEM arising through different patterns of generation dispatch;
- changes in Australia's greenhouse gas emissions;
- changes in involuntary load curtailment; and
- changes in costs for other parties.

This assessment did not rerun time-sequential market modelling, which was completed for the PACR. The effort and time to perform this modelling was not considered proportionate to the impact on the ranking of portfolio options, as the dispatch outcomes between portfolios is not expected to materially diverge since:

- Hydro re-dispatch hours occur primarily in synchronous condenser mode (i.e. no required pumping or generation of electricity which impacts energy market dispatch).
- Synchronous condensers do not participate in the energy market (the small auxiliary load would have an immaterial impact on energy market dispatch outcomes).
- There is no change to the generation and storage capacity outlook between portfolios (i.e. the solutions included in each portfolio option are also in the base case, and therefore the future generation mix does not vary between portfolio options).
- Gas re-dispatch is assumed to occur at minimum stable operating levels and used only as a last resort due to high marginal costs.

Each of the four key market benefit classes estimated are outlined in the sections below.

5.5.1.1. Changes in fuel consumption

Differences in fuel consumption between portfolio options reflect changes in the amount of synchronous machine dispatch required to meet system strength needs. Under portfolio options with more synchronous condensers and grid-forming batteries for the minimum level, less gas generation is re-dispatched, leading to reduced fuel consumption.

5.5.1.2. Changes in Australia's greenhouse gas emissions

Changes in Australia's greenhouse gas emissions were estimated based on the level of additional gas re-dispatch across each portfolio. The Value of Emissions Reduction (VER) adopted by Transgrid, consistent

⁷⁸ Regulatory investment test for transmission application guidelines, AER, November 2024, Section 3.7.1

with AEMO's 2026 ISP Inputs and Assumptions workbook, was then applied to the modelled level of re-dispatch, to quantify the associated emissions cost.⁷⁹ This is consistent with the approach taken in the PACR.

5.5.1.3. Changes in involuntary load curtailment

If the minimum level of system strength is not met, voltage control and protection systems may not operate correctly, in the worst case leading to cascading failures in the transmission network and widespread power outages. As such, involuntary load curtailment is modelled where the minimum level of system strength is not met. While the portfolio options assessed are specifically designed to avoid these outcomes, a residual risk of involuntary load curtailment remains under some portfolio options, and, in particular, under the base case where no action to meet the need is taken.

This assessment quantifies involuntary load curtailment based on violations to minimum level requirements using the same methodology applied in the PACR.⁸⁰ The Value of Customer Reliability (VCR) is applied to quantify the estimated economic value of avoided involuntary load curtailment for each portfolio option. This value has been updated based on the latest AER estimate.⁸¹

5.5.1.4. Changes in costs for other parties

For this assessment, changes in costs for other parties are tied to increases in variable operating and maintenance costs associated with the re-dispatch of hydro and gas units. These costs have been modelled using AEMO's 2026 ISP Inputs and Assumptions workbook,⁸² consistent with section 3.4 of the RIT-T guidelines.⁸³

5.5.1.5. Other market benefits are considered immaterial

The PACR also considered two further categories of market benefit:

- changes in voluntary load curtailment; and
- changes in network losses.

These categories were both found to be immaterial in the PACR assessment.⁸⁴ We have therefore excluded them from this MCC assessment as we do not consider anything has changed that would alter this conclusion.

The remaining market benefit classes identified in the RIT-T guidelines,⁸⁵ including competition benefits, option value and changes in ancillary service costs, were expected to be immaterial in the PACR and were excluded.⁸⁶ Transgrid has excluded these market benefit classes from this assessment as no change has occurred which would warrant a different approach.

5.5.2. Cost benefit analysis parameters adopted

The MCC assessment models a 20-year assessment period from FY31 to FY50, inclusive. FY31 is the earliest year that new solutions may be available, and so the approach to managing system strength solutions between FY26-30 will be common to all portfolio options.

⁷⁹ [2026 ISP Inputs and Assumptions workbook](#), AEMO, June 2026

⁸⁰ Baringa, August 2025, PACR - Baringa Market Modelling Report, pg. 27

⁸¹ [Value of customer reliability 2025 Annual Adjustment Summary](#), AER, December 2025

⁸² [2026 ISP Inputs and Assumptions workbook](#), AEMO, June 2026

⁸³ [Regulatory Investment Test for Transmission application guidelines](#) - Version 6, AER, November 2024

⁸⁴ [Meeting system strength requirements in NSW PACR](#), Transgrid, July 2025, Page 139

⁸⁵ Regulatory investment test for transmission application guidelines, AER, November 2024, Section 3.6

⁸⁶ [Meeting system strength requirements in NSW PACR](#), Transgrid, July 2025, Appendix F.9

A 20-year assessment period was selected to align to the duration of the modelling horizon in the system strength PACR. This period is commensurate to the size, complexity and expected lives of the assets delivered under the credible options assessed and provides for a reasonable indication of the costs and benefits over a long outlook period.

5.5.2.1. Annualised capital cost

Since the system strength PACR, Transgrid has aligned its approach to annualising and discounting costs with AEMO's ISP methodology. Under this methodology, the capital investment is converted into an equivalent annual annuity to allow like-for-like comparison on assets with different economic lives and different commissioning dates. Transgrid is required to follow the assumptions used by AEMO and has incorporated this methodology into this assessment.

In calculating this annuity, we have adopted the technology-specific real pre-tax weighted average cost of capital (WACC) estimates included in AEMO's 2025 Inputs, Assumptions and Scenarios Report (IASR). Specifically, we have adopted an assumed three per cent WACC for regulated transmission investments and eight per cent for battery projects in the Step Change scenario.⁸⁷

This methodology is different to the net market benefit assessment used in the PACR, which used a capitalised cost based on when it is incurred by Transgrid to deliver the solution (or procure the service for a non-network solution). The NPV workbooks for each assessment are provided on Transgrid's website.

Transgrid also completed the net present value assessment following the same methodology as the PACR to enable a like-for-like comparison, see Appendix C. This assessment showed the ranking of portfolio options is the same across both methodologies.

5.5.2.2. Discount rate

The AER Cost Benefit Analysis Guidelines require the discount rate used in the NPV analysis to be the commercial discount rate appropriate for the analysis of a private enterprise investment in the electricity sector. A central discount rate of seven per cent (real, pre-tax) has been used in the NPV analysis, consistent with the commercial discount rate in the 2025 IASR.

⁸⁷ [2026 Inputs, Assumptions and Scenarios workbook](#), AEMO, June 2026

6. Portfolio formation methodology

The following sections describe the methodology used in this MCC assessment to identify the composition of each system strength portfolio option.

Portfolio options were constructed to assess the need for each 'Phase 2' synchronous condenser, alongside re-dispatch of hydro and gas generators and grid-forming BESS towards the minimum level requirements.

6.1.1. Identifying the number of synchronous condensers

Five portfolio options were assessed, with each portfolio option including between one and five 'Phase 2' synchronous condensers, e.g. portfolio option 1a has one 'Phase 2' synchronous condenser, while portfolio option 5a has five 'Phase 2' synchronous condensers. The base case represents the portfolio option where zero 'Phase 2' synchronous condensers are included.

6.1.2. Identifying the amount of hydro and gas re-dispatch

For each portfolio option, power system studies were undertaken to assess the gap in system strength against Transgrid's minimum level system strength requirements.⁸⁸ The power system studies used coal duration curves derived from PACR market modelling to estimate the proportion of the year each number of coal units were online and then identified the residual system strength gap resulting. The coal duration curves did not consider material two-shifting or seasonal mothballing, as coal units which are offline due to economic decommitment are likely to be available for re-dispatch if this behaviour does occur, therefore would have no net effect on the risk of system strength gaps. A case study, set out in section 8.2, has been considered where greater economic decommitment results in a reduction in the availability of coal units.

In addition to the 'Phase 2' synchronous condenser(s) included in each portfolio option, hydro and then gas units were progressively added, in order of marginal cost between technologies, until the system strength requirements were met. The availability of hydro units was informed by recent procurement outcomes for re-dispatch. The availability of gas units was subject to modelled gas constraints based on practical supply and pipeline limitations. Further detail of the modelled constraints is provided in Section 4.3.2 and Appendix B.

Gas re-dispatch is the highest marginal cost system strength solution, therefore if gas constraints bind, there is limited alternative solutions available to meet system strength requirements. Where constraints were binding, a system strength gap was modelled. This gap was quantified as involuntary load curtailment for the net market benefits assessment, following the same methodology applied in the PACR.⁸⁹

6.1.3. Identifying the amount of grid-forming BESS for the minimum level

Grid-forming BESS are not currently considered technically feasible to meet minimum system strength requirements, as per the PACR, re-confirmed by AEMO's public position⁹⁰ and independent advice from Aurecon⁹¹ for Transgrid's system strength PACR. Aurecon's advice stated that the technical feasibility of grid-forming BESS for the minimum level was likely to be demonstrated by FY33.

⁸⁸ Transgrid's system strength requirements are defined by AEMO in its [Transition Plan for System Security](#) as per Clause 5.20C.1 of the National Electricity Rules.

⁸⁹ System Strength PACR Modelling Report, Baringa, August 2025, Page 29

⁹⁰ Transition plan for system security, AEMO, December 2025, Page 135


⁹¹ Advice on maturity of grid-forming inverter solutions for system strength, Aurecon, March 2024

If proven technically feasible for the minimum level of system strength, and located in areas of need, grid-forming BESS could provide a low-cost system strength solution by value stacking minimum level system strength support with other energy, ancillary market and efficient level system strength services.

Noting that this technology is not yet technically feasible, Transgrid has taken a risk-balanced approach to including grid-forming BESS as an available solution from FY33, to the extent that there are sufficient fallback hydro and gas re-dispatch solutions available to meet the need. This mitigates the risk of grid-forming BESS not performing as intended, or if their technical feasibility for the minimum level is not demonstrated in time.

The methodology to identify the optimal amount of grid-forming BESS for each portfolio option is illustrated in the figure below.

Figure 9. Methodology to identify the optimal amount of grid-forming BESS for each portfolio option



Steps 1 and 2 are designed to manage the risk stemming from when grid-forming BESS will demonstrate its technical feasibility for providing protection-quality fault current. Steps 1 and 2 identify if a portfolio option has sufficient fallback solutions, by testing the portfolio option without grid-forming BESS. Portfolio options without sufficient fallback solutions are removed from further analysis.

Transgrid's MCC assessment therefore provides a practical and prudent pathway for grid-forming BESS to contribute towards the minimum level of system strength requirements, while appropriately managing uncertainty and risk to the power system.

7. Portfolio options

This section outlines the outcomes of the portfolio formation process used to develop candidate portfolio options for net market benefit assessment. The portfolio formation process is undertaken in two-stages:

- **Stage (a):** this stage excludes the potential contribution of grid-forming BESS to the minimum level of system strength, as they are not currently considered technically feasible for minimum level provision. Stage (a) identifies technically feasible portfolio options; only feasible portfolio options carry forward for subsequent assessment in stage (b).
- **Stage (b):** this stage includes the contribution of grid-forming BESS to the minimum level from FY33, assuming confirmation of their technical feasibility. This is because there is a high likelihood that grid-forming BESS could form part of the preferred portfolio option if their technical feasibility was confirmed. This stage involves the identification of the optimal amount of gas and hydro re-dispatch and grid-forming BESS for the minimum level for each credible portfolio option.

Transgrid proposes to rely on grid-forming BESS only to the extent that there are sufficient alternative fallback solutions available to meet the need (i.e. available re-dispatch of hydro and/or gas), if grid-forming BESS feasibility is not confirmed. This is to ensure the system security risk associated with the uncertainty of when, or if, grid-forming BESS will become a feasible solution for the minimum level is managed.

The assessment of whether sufficient fallback solutions exist occurs in stage (a). Where there are insufficient fallback solutions, i.e. modelling shows a risk of system strength gaps, portfolio options are not deemed technically feasible and are removed from the stage (b) assessment.

As discussed in Section 6.1.3, this approach is used to ensure a feasible and secure portfolio is maintained if technical feasibility of grid-forming BESS towards the minimum level is delayed or does not eventuate.

7.1. Stage (a) determines technically feasible portfolio options

The first step in forming the portfolio options is to identify which portfolio options have sufficient fallback solutions to meet the need, without the contribution of grid-forming BESS to the minimum level. Five portfolio options were considered. The initial portfolio options are denoted with 'a' (e.g. portfolio option 1a), to differentiate them from portfolio options in which grid-forming BESS are included. We later identify portfolio options with a 'b' where grid-forming BESS are included.

Table 13. Portfolio options excluding grid-forming BESS

Portfolio option	0 (base case)	1a	2a	3a	4a	5a
‘Phase 2’ synchronous condensers						
Dinawan	-	1	1	1	1	1
Munmorah	-	-	1	1	1	1
Newcastle	-	-	-	1	1	1
Waratah West	-	-	-	-	1	1
Kemps Creek	-	-	-	-	-	1
Total	-	1	2	3	4	5
Re-dispatch of synchronous machines						
Hydro	Yes	Yes	Yes	Yes	Yes	Yes

Portfolio option	0 (base case)	1a	2a	3a	4a	5a
Gas	Yes	Yes	Yes	Yes	Yes	Yes
Grid-forming BESS for minimum level						
Sydney West region (MW)	-	-	-	-	-	-

Under the accelerated synchronous condenser scenario, Figure 10 to Figure 13 show the hydro and gas re-dispatch hours required between FY31-41 for each portfolio option. The figures present the results under both coal unit retirement scenarios (i.e., the 2026 ISP Step Change and Proponent Advised coal unit retirement scenarios). The modelling horizon extends to FY45, however there is minimal change for system strength in the power system beyond FY41, after all coal-fired power stations have retired in NSW. Accordingly, for readability, all graphs presented in this Report end at FY41.

The gas re-dispatch graphs delineate between 'feasible' gas re-dispatch and 'infeasible' gas re-dispatch, which reflects where modelled gas constraints have been violated. Periods of infeasible gas re-dispatch indicate a risk of system strength gaps and are quantified as involuntary load curtailment for the net market benefits assessment.

Under the assumed synchronous condenser timing scenario (i.e. delivery in FY34), the re-dispatch requirements between FY31 to FY33 for each portfolio option are represented by the base case ('portfolio option 0'), as there are zero 'Phase 2' synchronous condensers during this period.

Figure 10. 2026 ISP Step Change scenario. Hydro re-dispatch in years FY31 – 41, excluding grid-forming BESS




Figure 11. 2026 ISP Step Change scenario. Gas re-dispatch in years FY31 – 41, excluding grid-forming BESS




Figure 12. Proponent Advised coal unit retirement date scenario. Hydro re-dispatch in years FY31 – 41, excluding grid-forming BESS





Figure 13. Proponent Advised coal unit retirement date scenario. Gas re-dispatch in years FY31 – 41, excluding grid-forming BESS



The above assessment shows a significant reliance on both hydro and gas re-dispatch from FY34 onwards in the base case and portfolio options 1a and 2a (i.e. with less than three 'Phase 2' synchronous condensers), under both coal unit retirement date scenarios.

7.1.1. Difference in re-dispatch requirements between 2026 ISP Step Change and Proponent Advised coal unit retirement date scenarios between FY31-34

In the 2026 ISP Step Change coal retirement scenario, the assessment identifies a small number of hours of infeasible gas re-dispatch in the base case and portfolio option 1 in FY31, in the base case in FY32, and in the base case and portfolio option 1 in FY33. Although these infeasibilities occur for a limited number of hours, they indicate that the system is operating beyond its technical limits for some periods in these years. This highlights a risk of system strength gaps as coal generation retires and the system becomes increasingly reliant on gas generation to provide system strength. Infeasible levels of gas re-dispatch translate into a modelled risk of system strength gaps in these years.

Under the Proponent Advised coal unit retirement date scenario, there is more system strength provided by coal generators as a byproduct of their typical operation in the energy market, which reduces the need for re-dispatch of hydro and gas units from FY31 to FY33. No infeasible gas re-dispatch is observed between FY31 and FY33 under the Proponent Advised coal unit retirement scenario for either accelerated (FY31) or assumed synchronous condenser delivery timing (FY34). However, there is still a modelled risk of system strength gaps under the base case, portfolio option 1a and 2a from FY34 onwards (i.e. in portfolio options with less than three 'Phase 2' synchronous condensers).

7.1.2. Re-dispatch from FY34 onwards

From FY34, Mt Piper is the only NSW coal power plant assumed to remain in the system under both the ISP 2026 Step Change scenario and the Proponent Advised coal retirement date scenario.⁹²

Gas and hydro re-dispatch hours significantly increase from FY34 in the base case, under both coal unit retirement date scenarios, which coincides with the full retirement of Vales Point and Bayswater Power Stations. Hydro re-dispatch, predominantly in synchronous condenser mode, plays a sustained role in meeting system strength requirements in portfolio options with four or less 'Phase 2' synchronous condensers.

Gas re-dispatch is required when hydro re-dispatch is insufficient to meet the need. In portfolio options 3a, 4a and 5a (with three or more 'Phase 2' synchronous condensers installed), gas generator re-dispatch typically only occurs for periods of synchronous condenser maintenance or critical planned outages of transmission lines.

In the base case and portfolio options 1a and 2a (which contain less than three 'Phase 2' synchronous condensers), gas generator re-dispatch occurs for sustained periods to meet system strength requirements, exceeding physical gas pipeline limits and supply constraints. Infeasible levels of gas generator re-dispatch hours are modelled from FY34 onwards in the base case, portfolio options 1a and 2a, leading to the risk of system strength gaps and associated involuntary load curtailment. This indicates that portfolios with less than three 'Phase 2' synchronous condensers do not have sufficient fallback system strength solutions to manage the risk of gaps if grid-forming BESS do not perform.

⁹² Mt Piper is assumed to retire in FY36-38 under the 2026 ISP Step Change scenario and in FY41 under the Proponent Advised scenario.

7.1.3. Risk of system strength gaps

The tables below show the modelled risk of system strength gaps for each portfolio option (without grid-forming BESS), based on the range of coal retirement scenarios and synchronous condenser timing. Note that 'Phase 2' synchronous condensers are only available from FY34 under the assumed timing. 'FY35+' represents all years including and beyond FY35.

A modelled risk of system strength gaps is identified where the level of gas re-dispatch required exceeds the gas constraints.

Table 14. 2026 ISP Step Change scenario. Modelled risk of system strength gaps

Assumed synchronous condenser timing (delivery in FY34)							Accelerated synchronous condenser timing (delivery in FY31)						
Portfolio option	Base case	1a	2a	3a	4a	5a	Portfolio option	Base case	1a	2a	3a	4a	5a
FY31	Risk	Risk					FY31	Risk	Risk	No risk	No risk	No risk	No risk
FY32	Risk	<i>Note, 'Phase 2' synchronous condensers only available in FY34</i>					FY32	Risk	No risk	No risk	No risk	No risk	No risk
FY33	Risk						FY33	Risk	Risk	No risk	No risk	No risk	No risk
FY34	Risk	Risk	Risk	No risk	No risk	No risk	FY34	Risk	Risk	Risk	No risk	No risk	No risk
FY35+	Risk	Risk	Risk	No risk	No risk	No risk	FY35+	Risk	Risk	Risk	No risk	No risk	No risk

Table 15. Proponent Advised coal unit retirement scenario. Modelled risk of system strength gaps

Assumed synchronous condenser timing (delivery in FY34)							Accelerated synchronous condenser timing (delivery in FY31)						
Portfolio option	Base case	1a	2a	3a	4a	5a	Portfolio option	Base case	1a	2a	3a	4a	5a
FY31	No risk	No risk					FY31	No risk	No risk	No risk	No risk	No risk	No risk
FY32	No risk	<i>Note, 'Phase 2' synchronous condensers only available in FY34</i>					FY32	No risk	No risk	No risk	No risk	No risk	No risk
FY33	No risk						FY33	No risk	No risk	No risk	No risk	No risk	No risk
FY34	Risk	Risk	Risk	No risk	No risk	No risk	FY34	Risk	Risk	Risk	No risk	No risk	No risk
FY35+	Risk	Risk	Risk	No risk	No risk	No risk	FY35+	Risk	Risk	Risk	No risk	No risk	No risk

The objective of testing each portfolio option without grid-forming BESS is to identify which portfolio options have sufficient fallback system strength solutions (i.e. hydro and gas). Two 'Phase 2' synchronous condensers with an accelerated synchronous condenser timing (FY31) are required to mitigate the modelled risk of system strength gaps in FY31 and FY33 under the 2026 ISP Step Change scenario. From FY34, three synchronous condensers are required under both coal retirement scenarios. Therefore, portfolio options with less than three 'Phase 2' synchronous condensers are not considered credible and have been excluded from further assessment.

Note that, a modelled risk of system strength gaps may also ultimately result in a reliability gap. Where 'no risk' is identified, this indicates a modelled outcome based on the scenario. Changes to key assumptions may increase or decrease the risk of system strength gaps, and this analysis does not consider non-credible contingencies.

Delayed coal retirement dates under the Proponent Advised coal unit retirement scenario result in more units remaining in the market in years FY31-33. While system strength gaps were not identified in FY31-33 under proponent advised coal retirement dates, the risk of gaps occurring in practice may be greater than indicated by the modelling due to changes in synchronous generator operating behaviour. This may include increased frequency of two-shifting, seasonal mothballing and economic decommitment. These changes could increase the need for additional re-dispatch hours of synchronous machines to maintain system strength and in some circumstances, may lead to system strength gaps, if sufficient solutions are not available to meet requirements.

Note that this represents a modelled outcome in one potential state of the world. In the contracting timeframe, various aspects of the realised state of the world may diverge from the modelled state.⁹³ Transgrid will continue to apply reasonable endeavours to manage these risks through its procurement processes and collaborate with market and government bodies.

7.2. Stage (b) identifies the optimal amount of grid-forming BESS for the minimum level

Stage (b) of the assessment only considers the credible portfolio options which were selected for further assessment in stage (a), being portfolio options 3 to 5. For these credible portfolio options, with three to five 'Phase 2' synchronous condensers, blocks of 100 MW of grid-forming BESS located in the Sydney West region were progressively added, to identify the optimal amount that maximises net market benefits for each portfolio option.⁹⁴


To differentiate the three portfolio options from those without grid-forming BESS, these portfolio options are assigned the label 'b', e.g. 'portfolio option 3b' is the portfolio option which contains three 'Phase 2' synchronous condensers and grid-forming BESS contributing towards the minimum level.

Figure 14 shows how net market benefits vary as grid-forming BESS for the minimum level are progressively added to each of the portfolio options. The net market benefits of each portfolio option are discussed in detail in Section 8. The shape of the net market benefits curves below is similar across both coal unit retirement date scenarios and synchronous condenser timings. The optimal amount of grid-forming BESS for the minimum level of system strength is shown by a circle for each portfolio option.

⁹³ Due to differences compared to the modelled assumptions of for example IBR uptake, timing of the entry and exit of generation assets, the timing of transmission deployment etc. Note, this is a non-exhaustive list.

⁹⁴ Within the MCC assessment, these grid-forming BESS are considered as upgrades from generic BESS that are included within AEMO's 2026 ISP Step Change projections for the Sydney, Newcastle Wollongong region.

Figure 14. 2026 ISP Step Change coal retirement scenario. Identifying the optimal amount of grid-forming BESS for the minimum level of system strength



The benefit of adding grid-forming BESS to portfolio option 3b (containing three ‘Phase 2’ synchronous condensers) is significant, as it displaces higher-cost gas re-dispatch. For portfolio option 4b, there is a small added benefit from displacing hydro re-dispatch. There is no benefit for oortfolio Option 5b as the minimum level need is entirely met through synchronous condensers.

While 400 MW and 900 MW are identified as the optimal amounts of grid-forming BESS for portfolio options 4b and 3b respectively, net present value outcomes are effectively unchanged across a range of capacities. For portfolio option 4b, NPV outcomes are essentially equal for 300–500 MW of grid-forming BESS, while for portfolio option 3b, they are essentially equal for 500–1,200 MW. Consequently, the amount of grid-forming BESS services ultimately procured may vary from the ‘optimal’ amount identified in this assessment and will be reassessed during contracting and procurement, considering updated requirements and tender responses.

Note that only 5% of the capital cost of grid-forming BESS is considered in this assessment, consistent with the PACR (reflecting upgrade costs to enable grid-forming and protection quality fault current), as these BESS are already projected to enter the energy market under the 2026 ISP Step Change scenario (discussed in Section 4.2.3). The optimal amount of grid-forming BESS was the same for both coal retirement scenarios.

Table 16 shows the components of each portfolio option which include grid-forming BESS. The amount of grid-forming BESS included is based on the amount of grid-forming BESS which maximises net market benefits.

Table 16. Portfolio options with grid-forming BESS

Portfolio option	Base case	3b	4b	5b
'Phase 2' synchronous condensers				
Dinawan	0	1	1	1
Munmorah	0	1	1	1
Newcastle	0	1	1	1
Waratah West	0	0	1	1
Kemps Creek	0	0	0	1
Total	0	3	4	5
Re-dispatch of synchronous machines				
Hydro	Yes	Yes	Yes	Yes
Gas	Yes	Yes	Yes	Yes
Grid-forming BESS for the minimum level				
Sydney West region (MW)	0	900	400	0

8. Net market benefits assessment

The net market benefits for each portfolio option have been assessed for both coal unit retirement date scenarios and for both synchronous condenser timings.

Note all values presented in this document are on 30 June 2025 dollar cost basis, unless stated otherwise. Results in this section assume that the commercial feasibility of 'Phase 2' synchronous condensers is confirmed.

8.1. 2026 ISP Step Change coal unit retirement dates scenario


The following section details the net market benefits and costs of individual portfolio options for both accelerated (FY31) and assumed synchronous condenser delivery timing (FY34) under the 2026 ISP Step Change scenario. This net present value assessment is undertaken for portfolio options excluding ('a' portfolio options) and then including ('b' portfolio options) grid-forming BESS for the minimum level, to enable the additional value generated by grid-forming BESS to be observed.

8.1.1. Net market benefits excluding grid-forming BESS for the minimum level

The net present value assessment for each portfolio option without grid-forming BESS contributing to the minimum level is shown in Figure 15.

To interpret this chart, dark green bars represent benefits under the assumed delivery timing of 'Phase 2' synchronous condensers (in FY34). The benefits of accelerated synchronous condenser delivery (FY31) are represented as the summation of the benefits of the dark and light green bars (with the total noted above the light green bars).

Figure 15. 2026 Step Change coal retirement scenario. Net present value excluding grid-forming BESS in the portfolio



The magnitude of the benefits of each portfolio option indicates the severity of the risk to the power system under the base case, where gaps in system strength become increasingly apparent. The difference in present value between portfolio options 3a, 4a and 5a is relatively small compared to the total benefit each portfolio option provides.

Figure 15 identifies that portfolio option 4a maximises net market benefits (i.e. four 'Phase 2' synchronous condensers) under both the accelerated and assumed timing of synchronous condensers. This option would be selected as the preferred portfolio, when excluding grid-forming BESS contribution to the minimum level of system strength. Portfolio option 3a and 5a have the second and third highest net market benefits (\$251 million and \$90 million lower than portfolio option 4a under the accelerated synchronous condenser timing, respectively).


A significant reduction in net benefits is observed for portfolio options 1a and 2a, which are approximately \$43 billion and \$21 billion lower than portfolio option 4a, respectively. This outcome is primarily driven by the substantial costs associated with involuntary load curtailment resulting from these portfolio options being unable to satisfy system strength requirements. In these cases, system strength gaps arise due to infeasible levels of gas generator re-dispatch hours. The net market benefits assessment was also calculated without application of the gas constraints. This did not result in a change to the ranking of options. These results are shown in Appendix B.

While portfolio options 1a and 2a are not considered credible options, as they do not have sufficient fallback solutions to meet the system strength need, they have been displayed to highlight the risk of under procurement of system strength solutions.

Figure 16 presents the composition of the estimated net market benefits for portfolio option 4a with the accelerated synchronous condenser timing, relative to the base case. Avoided involuntary load curtailment (unserved energy) represents by far the largest component of net market benefits, contributing approximately \$44 billion. This highlights the importance of system strength and level of unserved energy that is expected without additional investment in system strength solutions.

The benefits associated with avoided fuel costs, avoided costs to non-RIT-T parties and avoided greenhouse gas emissions are comparatively smaller, contributing approximately \$290 million, \$529 million, and \$343 million, respectively. These benefits are associated with avoided gas and hydro re-dispatch.


Figure 16. 2026 ISP Step Change scenario. Composition of the estimated net market benefits for portfolio option 4a, relative to the base case



8.1.2. Net market benefits including grid-forming BESS for the minimum level

Figure 17 shows the net present value assessment for each technically credible portfolio option including grid-forming BESS for the minimum level. This analysis assumes that the technical feasibility of grid-forming BESS for minimum level provision is confirmed.

Figure 17. 2026 ISP Step Change scenario. Net present value assessment including grid-forming BESS




Portfolio option 3b has \$115 - \$117 million higher net present value benefits (under the accelerated and assumed synchronous condenser timing scenarios, respectively) than the preferred portfolio without grid-forming BESS contributing to the minimum level (portfolio option 4a). This indicates the increased market benefits associated with including grid-forming BESS towards minimum level requirements in the portfolio.

This increase is driven by low-cost grid-forming BESS upgrades avoiding the need for inclusion of a fourth ‘Phase 2’ synchronous condenser (reduced capital and operating costs) and gas re-dispatch (reduced fuel costs, variable operating costs, emissions costs). This justifies the shift from portfolio option 4a to portfolio option 3b as the preferred portfolio option,⁹⁵ and creates a practical pathway for grid-forming BESS to contribute towards minimum level requirements.

The net market benefits for portfolio option 3b are approximately \$803 million higher if the three ‘Phase 2’ synchronous condensers are delivered at the accelerated identified timing (FY31) compared to the assumed timing (FY34). This benefit is driven by avoided involuntary load curtailment associated with infeasible levels of gas re-dispatch leading to a modelled risk of system strength gaps in years FY31-33, prior to delivery of ‘Phase 2’ synchronous condensers and projected proven technical feasibility of grid-forming BESS.

The breakdown of net market benefits for the preferred option including grid-forming BESS (portfolio option 3b) is compared to the preferred option excluding grid-forming BESS (portfolio option 4a) under accelerated timing is shown in Figure 18. This highlights the benefits associated specifically to grid-forming BESS for the minimum level.

Figure 18. 2026 ISP Step Change scenario. Key changes in the composition of the estimated net market benefits for portfolio option 3b, compared to portfolio option 4a under accelerated synchronous condenser timing



If portfolio option 3b is selected, but grid-forming BESS do not ultimately prove technically feasible for the minimum level, then additional hydro and gas re-dispatch would be required to meet system strength requirements. This would result in a \$251 million lower net market benefit compared to if portfolio option 4a was originally selected. This could be considered the ‘regret cost’.

⁹⁵ Portfolio option 3b is the preferred portfolio option, on the assumption that the commercial feasibility of ‘Phase 2’ synchronous condensers is confirmed.

A simple probabilistic assessment has been undertaken to determine the required probability for demonstrating technical feasibility of grid-forming BESS which makes portfolio option 3b the preferred option over portfolio option 4b – this is termed the ‘minimum required probability threshold’.

Table 17. 2026 ISP Step Change scenario. Net present value comparison for Portfolio options 3 and 4 under assumed synchronous condenser timing

	Net present value if grid-forming BESS do not demonstrate technical feasibility for the minimum level (\$m)	Net present value if GFM BESS do demonstrate technical feasibility for the minimum level (\$m)
Portfolio option 3	43,848	44,245
Portfolio option 4	44,127	44,162

The minimum required probability threshold of grid-forming BESS demonstrating capability and being delivered by FY33, ‘X%’, is determined using the equations below.

$$\text{Expected NPV of 3b} = (1 - X) * 43,848 + X * 44,245$$

$$\text{Expected NPV of 4b} = (1 - X) * 44,127 + X * 44,162$$

where $X \geq 77\%$, Expected NPV of 3b is higher than the expected NPV of 4b

It is challenging to determine the probability of grid-forming BESS proving technically feasible; however, this analysis indicates that the minimum required probability threshold is not unreasonably high, at above 77% for the assumed synchronous condenser timing under the ISP 2026 coal retirement scenario, justifying selection of portfolio option 3b.⁹⁶

8.1.3. Portfolio costs including grid-forming BESS

The breakdown of costs by technology for each portfolio is tabulated below, assuming the commercial feasibility of ‘Phase 2’ synchronous condensers and the technical feasibility of grid-forming BESS to the minimum level is confirmed. All costs are presented in present value dollars (\$FY25). Total expenditure is lowest for portfolio option 3b, under both the accelerated and assumed synchronous condenser delivery timings.

⁹⁶ This finding is consistent across all modelled scenarios, with the minimum required probability threshold being lower in the other scenarios: 76% for the Proponent Advised coal retirements scenario with assumed synchronous condenser timing, and under accelerated synchronous condenser timing, 71% and 66% for the Step Change and Proponent Advised coal retirements scenarios, respectively.

Table 18. 2026 ISP Step Change scenario. Present value portfolio costs⁹⁷

Portfolio	Portfolio option 3b		Portfolio option 4b		Portfolio option 5b	
Timing of synchronous condensers	Accelerated (FY31)	Assumed (FY34)	Accelerated (FY31)	Assumed (FY34)	Accelerated (FY31)	Assumed (FY34)
Network expenditure – ‘Phase 2’ synchronous condensers						
CAPEX (\$m)	318	239	423	319	529	398
OPEX (\$m)	44	33	59	44	73	55
Total (\$m)	362	272	482	363	603	453
Non-network expenditure – grid-forming BESS						
CAPEX (\$m)	32		14		0	
OPEX (\$m)	0		0		0	
Total (\$m)	32		14		0	
Non-network expenditure – Re-dispatch from synchronous generators						
CAPEX (\$m)	0	0	0	0	0	0
OPEX (\$m)	5	897	2	908	1	926
Total (\$m)	5	897	4	908	1	926
Total expenditure						
CAPEX (\$m)	350	271	438	333	529	398
OPEX (\$m)	49	930	63	952	74	981
Total (\$m)	398	1,202	501	1,285	604	1,379

8.2. Proponent Advised coal unit retirement dates scenario


The following section details the net market benefits and costs of individual portfolio options for both accelerated (FY31) and assumed (FY34) synchronous condenser delivery dates under the Proponent Advised coal unit retirement scenario. The net present value assessment for portfolio options excluding and then including grid-forming BESS for the minimum level is shown in this section, to enable the additional value generated by grid-forming BESS to be observed.

⁹⁷ Note that this assessment (and Table 18Table 18) converted all capital costs into an equivalent annual annuity, consistent with the methodology employed for the Final 2026 ISP, before discounting to a present value cost. This methodology is different to the net market benefit assessment used in the PACR, which used a capitalised cost. See Section 5.5.2 for additional details.

8.2.1. Net market benefits excluding grid-forming BESS for the minimum level

The net present value assessment for each portfolio option excluding grid-forming BESS contributing to the minimum level is shown in Figure 19. The dark green bars represent net market benefits accrued under the assumed delivery timing of 'Phase 2' synchronous condensers (in FY34). The additional benefits associated with accelerated delivery of synchronous condensers (FY31) are in light green.

Figure 19. Proponent Advised coal unit retirement scenario. Net present value assessment excluding grid-forming BESS




Portfolio option 4a, which includes four 'Phase 2' synchronous condensers, maximises the net market benefits. This is consistent with results under the 2026 ISP Step Change scenario, however the difference between portfolio option 3a and 4a is reduced under this scenario. The benefit of accelerated delivery of synchronous condensers is also reduced. This is due to the later timing of coal generator retirements, which provide additional system strength during typical market operations in FY31 to FY33. As a result, the avoided levels of system strength gaps and associated involuntary load curtailment, fuel costs and emissions that synchronous condensers displace during this period is reduced relative to the scenario with earlier coal generator retirement dates.

Again, portfolio options 1a and 2a have significantly lower net market benefits than portfolio option 4a (i.e. approximately \$37 billion and \$17 billion lower, respectively). This is due to significant involuntary load curtailment occurring under these portfolio options without sufficient system strength solutions available. Portfolio option 2a does reduce the involuntary load curtailment observed under the base case and Portfolio option 1a but still maintains significant involuntary load curtailment.

The net present value assessment for portfolio option 4a under the accelerated synchronous condenser timing, compared to the base case is shown in Figure 20 broken down by market benefit class.


Figure 20. Proponent Advised coal retirement scenario. Composition of estimated net present value for portfolio option 4a in comparison to the base case under accelerated timing



8.2.2. Net market benefits including grid-forming BESS for the minimum level

The net market benefits for each portfolio option including grid-forming BESS are shown below. This analysis assumes that their technical feasibility for minimum level provision is confirmed. Portfolio option 1b and portfolio option 2b are excluded from this analysis, as they do not sufficiently meet system strength requirements.

Figure 21. Proponent Advised coal retirement scenario. Net present value assessment with grid-forming BESS




Portfolio option 3b, which includes three 'Phase 2' synchronous condensers and 900 MW of grid-forming BESS for the minimum level of system strength, is the portfolio option with the highest market benefit under the Proponent Advised coal unit retirement scenario. This is consistent with modelled outcomes of the 2026 ISP Step Change scenario. This indicates that portfolio option 3b remains the preferred portfolio option across

the range of coal generator retirement dates assessed,⁹⁸ demonstrating its robustness to variations in retirement timing.

The increased benefit of accelerated synchronous condenser timing is smaller under the Proponent Advised coal unit retirement scenario compared to the 2026 ISP Step Change scenario. This is due to the extended coal operation during FY31-33, which reduces the cost associated with avoided involuntary load curtailment, fuel usage and emissions production which are attributed to accelerated synchronous condenser delivery.

The breakdown of net market benefits for the preferred option including grid-forming BESS (portfolio option 3b) to the preferred option excluding grid-forming BESS (portfolio option 4a) is compared in Figure 22 to demonstrate the benefits associated specifically with inclusion of grid-forming BESS.

Figure 22. Proponent Advised coal retirement scenario. Key changes in the composition of the estimated net market benefits for portfolio option 3b, compared to portfolio option 4a under accelerated timing



8.3. Discussion of coal unit retirement dates

This MCC assessment has included two coal unit retirement scenarios:

- Under the 2026 ISP Step Change coal retirement scenario, there is a modelled risk of system strength gaps from FY31 in the base case. ‘Phase 2’ synchronous condensers are required from FY31 to meet this need.
- The later Proponent Advised coal unit retirement scenario showed no modelled risk of system strength gaps in years FY31-33 (where the scenarios diverged), delaying the need for synchronous condensers until FY34 (though there are still higher net benefits if they can be delivered earlier).

Transgrid has explored other coal unit retirement assumptions during this assessment, even beyond Proponent Advised dates. If both Bayswater and Vales Point units were to delay their retirement dates

⁹⁸ Portfolio option 3b is the preferred portfolio option, on the assumption that the commercial feasibility of ‘Phase 2’ synchronous condensers is confirmed.

beyond FY34, we expect the need for 'Phase 2' synchronous condensers will also be deferred commensurately.

Extended coal retirement dates are not expected to change the preferred portfolio composition in isolation, only the timing of the need for 'Phase 2' synchronous condensers and level of hydro and gas re-dispatch. However, deferred investment does provide more time for alternative solutions, including grid-forming BESS or emerging synchronous machines with synchronous condenser capability, to demonstrate technical and commercial feasibility and/or become committed.

Importantly, this assessment assumes a similar level of coal unit reliability and operational output could be maintained if coal retirements extend. As noted in Section 2.2.2, AEMO has identified that ageing coal generators present an increasing risk of unavailability and that more flexible operating practices of coal units (expected as the penetration of renewables increases) can accelerate equipment degradation.

This reinforces the importance of maintaining a portfolio that is robust to both timing uncertainty and operational variability of coal units, rather than relying on any single retirement trajectory. In practical terms, the preferred portfolio in this MCC assessment reflects a balance between deferring system strength investment where possible and ensuring sufficient system strength capability is available ahead of key transition points, where the risks of under-procurement are materially higher than the costs of early investment.

8.4. Inertia assessment

In the PACR, Transgrid identified the addition of flywheels to each synchronous condenser (for stable voltage waveform support) will enable inertia requirements in NSW to be met.⁹⁹ This analysis was repeated for Portfolio option 3b with assumed 'Phase 2' synchronous condenser delivery (FY34). The analysis validated that a reduction from five to three 'Phase 2' synchronous condensers is still forecast to meet NSW's inertia requirements.

Additional information on meeting inertia requirements can be found in the PACR.¹⁰⁰

⁹⁹ [Meeting system strength requirements in NSW](#), Transgrid, July 2025, Page 71

¹⁰⁰ [Meeting system strength requirements in NSW](#), Transgrid, July 2025, Pages 32-33, 69

9. Case studies


This section includes two case studies that explore specific uncertainties related to coal unit retirement timing and the timing of system strength solutions. The case studies examine:

- Asymmetric risk of system strength adequacy at transition points.
- System strength adequacy with reduced coal unit output.

9.1. Case study 1: Asymmetric risk of system strength adequacy at transition points

The retirement of each coal generator represents a key transition point for the power system. Based on Proponent Advised timing, both Vales Point and Bayswater are planned to retire in CY33 (i.e., between late FY33 and early FY34), making this a critical period for managing system strength. Preparation is needed ahead of the transition point to ensure that any unexpected outcomes during commissioning or early operation of replacement system strength solutions are well-understood (including gaining experience in AEMO and Transgrid control rooms).

Figure 23. Key transition period for managing system strength in NSW



There are multiple drivers of uncertainty in this period, including uncertainty regarding the timing of coal generator retirements, synchronous condenser delivery and timing for the proven technical feasibility of grid-forming BESS towards the minimum level requirements. Multiple scenarios may eventuate where coal unit retirements occur before replacement solutions are delivered. These factors could include:

- Catastrophic failure of one or more coal units as they approach end of technical life.
- Less favourable market conditions for coal generators incentivising early retirement.
- Extended duration of regulatory processes, including contingent project applications and MCC obligations, delaying the delivery of 'Phase 2' synchronous condensers.
- Disruptions to international supply chains, or unexpected delays during project delivery, delaying when 'Phase 2' synchronous condensers are operational.

- Technical feasibility of grid-forming BESS for the minimum level requiring wide-spread changes to protection schemes or changes to inverter hardware.
- Grid-forming BESS projects in the Sydney West region fail to materialise or are delayed during project development or delivery.


This case study assesses the cost of meeting minimum level system strength requirements if Vales Point and Bayswater retirements occur before replacement system strength solutions are in place. Four case studies have been explored on Portfolio Option 3b, with FY34 used as a reference year.

Table 19. Four case studies exploring the sequencing of system strength solutions and the retirement of Vales Point and Bayswater

#	Case study	'Phase 2' synchronous condensers deployed	Grid-forming BESS deployed
A	Both replacement solutions are in place before coal retires	3	900 MW
B	Coal retires before grid-forming BESS are proven technically feasible, but after 'Phase 2' synchronous condensers are in place	3	0
C	Coal retires before 'Phase 2' synchronous condensers, but after grid-forming BESS are proven technically feasible	0	900 MW
D	Coal retires before both replacement solutions are in place	0	0

The net present cost of managing system strength following the retirement of Vales Point and Bayswater is shown for a single year in Figure 24, for each case study.

Figure 24. Cost to meet system strength requirements for a one-year period, following the retirement of Bayswater and Vales Point



In Case Study D, where Bayswater and Vales Point retire before either replacement solution is delivered, there is a modelled risk of system strength gaps because of insufficient available system strength solutions. The cost associated with system strength for one year in this state of the world is \$4 billion, with significant costs due to involuntary load curtailment.

In Case Study C, if the 900 MW of grid-forming BESS for the minimum level component of the portfolio option is found to be technically feasible and delivered in time for the retirement of Bayswater and Vales Point, but not 'Phase 2' synchronous condensers, then the economic cost is \$931 million. Involuntary load curtailment represents the largest cost component, which is a result of insufficient system strength solutions being available, though is substantially less than in Case Study D.

In Case Study B, the cost to manage system strength with 'Phase 2' synchronous condensers deployed but no grid-forming BESS is \$44 million, with no modelled risk of system strength gaps. Instead, the largest cost component relative to Case Studies C and D is the annualised Capex and Opex for the 'Phase 2' synchronous condensers, totalling \$43 million. The remaining \$1 million difference is attributed to the costs associated with additional re-dispatch hours of synchronous units which are enabled to meet system strength requirements in the absence of grid-forming BESS for the minimum level.

In Case Study A, if grid-forming BESS are then added, the re-dispatch requirements for gas and hydro generators to meet system strength requirements reduces, reducing the net modelled economic cost to \$27 million; this represents the core scenarios modelled in this MCC assessment. The difference between Case Study A and Case Study B, with and without grid-forming BESS, is \$17 million, this represents the annual cost risk if grid-forming BESS are not proven technical feasibility on time or do not perform as modelled, assuming 'Phase 2' synchronous condensers are delivered in time.

Comparing the cost with and without system strength solutions highlights the asymmetric risk of system strength, particularly at key transition points such as coal retires. As the AEMC Reliability Panel stated in 2025, *"...the risks of over- and under-investment are asymmetric. The risk of over-investment in security services, or investment earlier than needed, comes with much lower costs than under-investment or investment that is too late. Under-investment could lead to periods when the NEM cannot be securely operated."*¹⁰¹

This case study further reinforces the importance of timely delivery of system strength solutions ahead of key transition points, to enable key transition points to be appropriately managed. Results show that if sufficient system strength solutions cannot be delivered ahead of coal generator retirements, then the risk of system strength gaps occurs; in this case, intervention may be required to ensure the grid may be safely and securely operated. This would impact upon wholesale markets and investment signals for new generation, storage and network assets. These impacts have not been modelled.

9.2. Case study 2: System strength adequacy with reduced coal unit output

This case study has assessed the modelled risk of system strength gaps in the hypothetical scenario where there are two less coal units available for system strength provision in each year relative to each of the 2026 ISP Step Change and Proponent Advised coal unit retirement scenarios. This may occur due to faster than anticipated coal unit retirements, unexpected failures, or material seasonal mothballing where units are unable to return to service in time to address system strength gaps. Seasonal mothballing is likely to occur

¹⁰¹ Letter to AEMO: Reliability Panel comments on AEMO's Transition Plan for System Security, AEMC Reliability Panel, April 2025

in spring and autumn, when wholesale electricity prices are typically lowest; this also coincides with the periods where the system strength need is greatest.

The methodology used for this case study is identical to the core methodology, with grid-forming BESS for the minimum level excluded from this assessment, and the modelled risk of system strength gaps identified in years where gas re-dispatch exceeded feasible levels. This case study (with two less coal units available) has been undertaken on both the 2026 ISP Step Change scenario and the Proponent Advised coal unit retirement scenario.

Table 20. 2026 ISP Step Change scenario. Risk of system strength gaps under case study 2

Assumed synchronous condenser timing (delivery in FY34)							Accelerated synchronous condenser timing (delivery in FY31)						
Portfolio option	Base case	1a	2a	3a	4a	5a	Portfolio option	Base case	1a	2a	3a	4a	5a
FY31	Risk	Risk					FY31	Risk	Risk	Risk	No risk	No risk	No risk
FY32	Risk						FY32	Risk	Risk	No risk	No risk	No risk	No risk
FY33	Risk						FY33	Risk	Risk	No risk	No risk	No risk	No risk
FY34	Risk	Risk	Risk	Risk	No risk	No risk	FY34	Risk	Risk	Risk	Risk	No risk	No risk
FY35+	Risk	Risk	Risk	No Risk	No risk	No risk	FY35+	Risk	Risk	Risk	No Risk	No risk	No risk

Table 21. Proponent Advised coal unit retirement scenario. Risk of system strength gaps under case study 2

Assumed synchronous condenser timing (delivery in FY34)							Accelerated synchronous condenser timing (delivery in FY31)						
Portfolio option	Base case	1a	2a	3a	4a	5a	Portfolio option	Base case	1a	2a	3a	4a	5a
FY31	Risk	Risk					FY31	Risk	Risk	No risk	No risk	No risk	No risk
FY32	Risk						FY32	Risk	No risk	No risk	No risk	No risk	No risk
FY33	Risk						FY33	Risk	Risk	No risk	No risk	No risk	No risk
FY34	Risk	Risk	Risk	Risk	No risk	No risk	FY34	Risk	Risk	Risk	Risk	No risk	No risk
FY35+	Risk	Risk	Risk	No risk	No risk	No risk	FY35+	Risk	Risk	Risk	No risk	No risk	No risk

The results show that a risk of system strength gaps is modelled to occur in the base case across all years of the study (FY31 onwards) under both coal unit retirement date scenarios.

Under assumed synchronous condenser delivery timing, gaps remain in both the Step Change and Proponent Advised scenarios until synchronous condensers are delivered in FY34. The gaps are mitigated in FY34 with 4 or more 'Phase 2' synchronous condensers (i.e. portfolio option 4a and 5a). In FY35, gaps are mitigated in portfolio option 3a, 4a and 5a.

Under accelerated synchronous condenser timing, gaps remain across all years with delivery of only one 'Phase 2' synchronous condenser (portfolio option 1a) except for in FY32 if coal unit retirements follow proponent advised dates. In portfolio option 2a, gaps remain in FY31, FY34 and FY35 under the Step Change scenario and under FY34 and FY35 under the Proponent Advised scenario. In portfolio option 3a, gaps remain in FY34 under both the Step change and Proponent Advised scenarios. All modelled gaps are

mitigated within portfolio option 4a and 5a under both coal retirement date scenarios if synchronous condenser delivery is accelerated.

The modelled risk of gaps is most significant under the 2026 Step Change scenario in years FY31–33, prior to delivery of synchronous condensers (under the assumed synchronous condenser timing of FY34). The quantified cost of involuntary load curtailment rose from a total of \$440 million to \$2.97 billion across these years compared to the core analysis in Section 8. This analysis identifies modelled gaps in system strength that may ultimately result in a reliability gap.

The high economic cost associated with the modelled risk of system strength gaps under a reduced coal output 2026 ISP Step Change scenario highlights the vulnerability of the system to changes in coal assumptions. This risk can be addressed through accelerated procurement of system strength solutions to increase the resilience of the power system, if feasible.

10. Sensitivity analysis

This section explores the impact on net benefits of changes to two further assumptions; one being changes in the system strength solution for New England REZ and the other being synchronous condenser costs. By testing the robustness of the preferred portfolio to these changes, we can understand whether, should these changes occur, they are likely to constitute a further MCC in line with Clause 5.1.6.4(z4)(3).

10.1. New England REZ sensitivity


AEMO's 2026 ISP Step Change scenario IBR forecast for New England REZ is lower than EnergyCo's forecast.¹⁰²

Assumptions for New England REZ development in the core analysis of this MCC assessment are based on AEMO's latest published ISP (2026 Final ISP), as per the RIT-T guidelines. However, this sensitivity tests the impact of EnergyCo procuring synchronous condensers, to facilitate the higher New England REZ IBR forecast, on the ranking of portfolio options to meet minimum system strength requirements on Transgrid's transmission backbone.

10.1.1. New England REZ planning uncertainty

EnergyCo has a higher forecasted uptake of solar and wind generation in New England REZ compared to AEMO's 2026 Final ISP Step Change Scenario.¹⁰³ The IBR planned for in the latest version of each report is shown in Figure 25.

Figure 25. Forecasted IBR for the New England REZ



EnergyCo has signalled a requirement for prospective New England REZ projects to be capable of a withstand short circuit ratio of 1.2, met either behind-the-meter or via contracts in-front-of-the-meter.¹⁰⁴ At

¹⁰² [2025 Infrastructure Investment Objectives Report](#), AEMO Services Limited, 2025

¹⁰³ Information is based on [2025 Infrastructure Investment Objectives Report](#) (IIO, Page 50) and via joint planning.

¹⁰⁴ [Indicative Technical Requirements for generation and storage connections in New England Renewable Energy Zone](#), EnergyCo, December 2025, Page 8

this SCR, a proponent's system strength charge is zero under the NER. Grid-forming BESS is expected to be the primary solution to enable projects to achieve this.

Grid-forming BESS alone (no synchronous condensers) may be sufficient to support the efficient level requirements for AEMO's planned level of solar and wind in the 2030s (~6.5 GW). However, there is uncertainty if grid-forming BESS alone can remediate the higher level of IBR planned for by EnergyCo (~9.1 GW as per the 2025 IIO Report). Transgrid and EnergyCo are undertaking joint planning to identify the optimal solution to support stable voltage waveforms.

10.1.2. Sensitivity assumptions


As the system strength solution for New England REZ is uncertain, Transgrid has included a sensitivity in this report which assesses the contribution from potential synchronous condensers in New England REZ to the rest of the transmission backbone (if deployed), to assess whether this would change the ranking of portfolio options for this MCC assessment.

For this sensitivity, Transgrid has modelled two synchronous condensers in the New England REZ from FY35. This timing is based on the Proponent Advised timing for New England REZ when they would be required, and the need for two synchronous condensers were estimated from insights gained through EMT modelling for the system strength PACR.¹⁰⁵

10.1.3. Sensitivity results

The net market benefits assessment is shown in Figure 26.

Figure 26. 2026 ISP Step Change scenario. Net present value assessment for the New England REZ sensitivity



The net market benefits of portfolio options 3b to 5b are reduced by \$21 billion compared to the core modelling (which assumes no synchronous condensers are deployed in New England REZ), however there is no change to the ranking of portfolio options, with 3b being the preferred portfolio option. This indicates that the outcomes of Transgrid's MCC assessment, being three 'Phase 2' synchronous condensers and 900 MW of grid-forming BESS in the preferred portfolio are robust when additional synchronous condensers are also installed in New England REZ.

¹⁰⁵ [2026 ISP Appendix A5. Network Investments](#), AEMO, June 2026, Page 31

10.2. Sensitivity on higher and lower ‘Phase 2’ synchronous condensers costs

This sensitivity assesses whether the ranking of portfolio options change when there is a 40% increase, or a 30% decrease in synchronous condenser costs, relative to the central estimate within this MCC assessment. This percentage change has been selected as it reflects the current estimate accuracy range for the revised synchronous condenser cost. The net present value results for each portfolio option, including grid-forming BESS, are shown below.

Figure 27. 2026 ISP Step Change scenario. Net present value including grid-forming BESS with 40% higher synchronous condenser costs





Figure 28. 2026 ISP Step Change scenario. Net present value including grid-forming BESS with 30% lower synchronous condenser costs



The ranking of portfolio options (with portfolio option 3b being preferred, conditional on commercial feasibility being resolved) does not change under either the decreased or increased synchronous condenser cost sensitivity.

11. Selecting the preferred portfolio

This MCC assessment applies a structured decision framework to identify the preferred portfolio option (subject to confirmation of technical and commercial feasibility). This framework integrates power systems modelling and a net present value assessment to manage key uncertainties of coal unit retirement dates, synchronous condenser delivery timing and the timing of demonstrating the technical feasibility of grid-forming BESS for the minimum level.

To manage these uncertainties, Transgrid:

- developed a two-stage process to exclude portfolio options which did not have sufficient fallback solutions to meet minimum level system strength requirements without grid-forming BESS. Based on this, portfolio options with fewer than three 'Phase 2' synchronous condensers were not deemed credible based on the assumptions of this MCC assessment; and
- assessed the credible portfolio options under two coal unit retirement scenarios and two synchronous condenser delivery timings.

This assessment identified portfolio option 3b as the preferred portfolio option to meet system strength requirements, subject to the commercial feasibility of 'Phase 2' synchronous condenser being resolved. This portfolio option is comprised of three 'Phase 2' synchronous condensers, 900 MW of additional grid-forming BESS for the minimum level and contracts with hydro and gas generators.

This portfolio option has sufficient fallback solutions, in the form of further hydro and gas re-dispatch to manage grid-forming BESS uncertainty. The portfolio option also maximises the deployment of grid-forming BESS to displace higher-cost alternatives. The introduction of grid-forming BESS for the minimum level, instead of a fourth synchronous condenser and additional hydro and gas re-dispatch, is modelled to reduce the portfolio option cost by \$118 million, based on the assumed timing of 'Phase 2' synchronous condensers (if commercial credibility for the remaining synchronous condensers is resolved).

Portfolio option 3b is the preferred option under both coal unit retirement scenarios, both synchronous condenser delivery timings, the New England REZ Stage 2 sensitivity and the synchronous condenser cost sensitivity, subject to commercial feasibility. This highlights the robustness of the portfolio option across potential future MCCs, within the bounds of the assumptions tested in this MCC assessment. Details of the preferred portfolio option 3b are listed below, relative to the PACR preferred option.

Table 22. Details of the preferred portfolio option in this MCC assessment

Technology	Number	Timing	Location
'Phase 2' synchronous condensers	Three, dependent on commercial feasibility being resolved. Reduction from five in the PACR to three.	To be delivered by FY34, following the assumed timing under the NER process, or earlier if feasible. If acceleration is feasible, by FY31 to close the modelled risk of system strength gaps between FY31-33, as	Sites of the three 'Phase 2' synchronous condensers are Dinawan, Munmorah and Newcastle. ¹⁰⁶

¹⁰⁶ Consistent with the PACR, the locations of synchronous condensers in the Sydney/Newcastle region may change as detailed site feasibility studies continue to ensure the optimal locations are progressed.

Technology	Number	Timing	Location
		modelled under the AEMO 2026 ISP coal retirement timing.	
Grid-forming BESS	900 MW for the minimum level of system strength, once technical feasibility is confirmed. An increase from 0 MW for the minimum level, in addition to 5 GW for the efficient level that remains in the preferred portfolio.	Modelled from FY33 based on independent advice from Aurecon, but if technical feasibility can be proven earlier, this will increase benefits further.	Sydney West region – connected to the transmission network is considered most beneficial.
Modifications to synchronous machines to enable synchronous condenser mode	650 MW – as identified in the PACR.	From FY29	Projects located closer to the Sydney West node are considered more beneficial.

Consistent with the PACR, hydro and gas re-dispatch remains part of the preferred portfolio option in the early 2030s. The need for coal re-dispatch in the same period will be re-evaluated in the contracting timeframe. Transgrid will procure system security services from synchronous machines in the contracting timeframe based on the latest information and unit availability from all technologies.

The results of this MCC assessment are a revision to the PACR preferred option (on the condition that commercial feasibility of 'Phase 2' synchronous condensers can be resolved), rather than a fundamental change. The technologies remain unchanged, but the composition and proportions of each technology have been refined. This refinement is summarised as a reduction in synchronous condensers, substituted by an increased role for grid-forming BESS. The need for hydro, gas and potentially coal re-dispatch is consistent with the PACR, with the actual levels to be defined in the contracting timeframe.

The preferred portfolio option is robust to changes to various assumptions tested in this MCC assessment. This includes coal unit retirement dates between the two scenarios, the delivery timing of synchronous condensers between FY31–34, additional system strength solutions in New England REZ and tested for further synchronous condenser cost increases of up to 40%.

12. Additional non-network options could further change the optimal portfolio in the future

Transgrid recognises that maintaining optionality and flexibility to pivot away from solutions in the preferred portfolio towards lower cost alternatives, where possible, and within the time frame required, is firmly in the interests of consumers. Transgrid will continue to investigate options to maintain flexibility as part of the next steps for the project. Transgrid will also continue to monitor for material changes in circumstances that may impact the preferred option.

The section below presents an indicative assessment of what future alternative solutions could constitute a material change in circumstances and further reduce the need for 'Phase 2' synchronous condensers further.

12.1. Non-network solutions already within the revised preferred portfolio

This MCC assessment has re-assessed the preferred portfolio based on updated cost and timing assumptions for synchronous condensers, as well as the revised coal unit retirement schedule under the 2026 ISP Step Change scenario. Identification of the revised preferred portfolio is conditional on the commercial feasibility of 'Phase 2' synchronous condensers being resolved.

As a result of this MCC assessment, Transgrid has reduced the number of 'Phase 2' synchronous condensers in the portfolio – namely:

- The fifth 'Phase 2' synchronous condenser is no longer required because of the expected delay to the retirement of NSW coal generators as per the 2026 ISP, which provides sufficient time for the entry of synchronous condensers in Central West Orana REZ and the connection of new transmission projects which facilitate the flow of system strength in NSW.
- The fourth 'Phase 2' synchronous condenser has been removed because of the inclusion of 900 MW of grid-forming BESS for the minimum level in the portfolio (which increases net market benefits).

Non-network solutions included within the revised preferred portfolio include:

- 650 MW of synchronous machine modifications to enable synchronous condenser mode;
- 5 GW of grid-forming BESS for the efficient level;
- 900 MW of grid-forming BESS for the minimum level; and
- contracts with existing and committed synchronous machines for re-dispatch.

12.2. Possible alternative solutions to 'Phase 2' synchronous condensers if proven technically and commercially feasible

Transgrid has identified three potential future changes which could lead to a reduction in the number of 'Phase 2' synchronous condensers within the revised preferred portfolio and lead to a higher market benefit outcome.

- If at least 500 MW of synchronous machines with synchronous condenser capability emerge in the Sydney / Newcastle region (or larger capacity but outside of the region). This is in addition to the 650 MW of synchronous machines with synchronous condenser capability across southern NSW that were identified in the PACR.

- If an additional 950 MW of grid-forming BESS for the minimum level (in addition to the 900 MW already included in the preferred portfolio of this MCC assessment) emerges in the Sydney / Newcastle region and there is additional evidence to confirm their technical feasibility such that fallback solutions are not required.
- If sufficient coal generator units extend their Proponent Advised retirement dates beyond 2033 and this is expected to be included in the Step Change scenario in a subsequent AEMO IASR or ISP update.

Note that this list is not exhaustive. The exact amount required of a future solution will be dependent on its size, location on the grid, critical contingency and electrical characteristics.

Until a contingent project application is submitted to the AER (on the preferred portfolio once commercial feasibility is resolved), additional technically and commercially feasible non-network options may emerge that could warrant a further revision to the preferred portfolio (i.e. which would then impact what is included within any contingent project application submitted to the AER), provided they demonstrate technical and commercial feasibility. To reasonably be expected to affect the preferred portfolio, an emerging solution would need to demonstrate it is a technically and commercially feasible solution and can meet the following criteria:

- be assessed as technically feasible;
- have a proponent;
- have a sufficient system strength contribution to displace one or more synchronous condensers either individually or as a portfolio with other solutions;
- be highly likely to be available at or before the date of the 'Phase 2' synchronous condensers; and
- be cost-competitive with 'Phase 2' synchronous condensers.

Note that this doesn't preclude non-network solutions which have a system strength contribution smaller than one synchronous condenser from being included in a revised preferred portfolio. For example, their inclusion may achieve positive market benefits by reducing the need for additional re-dispatch of synchronous machines.

The following sections explore three potential future changes which could lead to a reduction in the number of 'Phase 2' synchronous condensers and a revision of the preferred portfolio.

12.2.1. Synchronous machines with synchronous condenser mode enablement

Synchronous machines may install a clutch to enable operation in synchronous condenser mode, where the turbine spins to contribute system strength without generating electricity. This functionality already exists for some hydro units in NSW. In addition, new synchronous plant may be fitted with synchronous condenser capability, or synchronous generators may convert at end-of-life to a synchronous condenser. Synchronous condenser mode modifications are bespoke and are not always technically feasible based on the design or age of the plant. It is therefore essential that the technical feasibility can be demonstrated during a MCC reassessment process.

The PACR included within the preferred portfolio the modification of 650 MW of plant in southern NSW to enable synchronous condenser mode, based on non-network expressions of interest throughout the RIT-T process. If additional solutions materialise and can meet the criteria identified, this may constitute a material change in circumstances.

Fault level analysis has been conducted to identify the indicative number of synchronous machines to provide the equivalent fault current to the two minimum level 'Phase 2' synchronous condensers, based on where the synchronous machines are in NSW. This number is in addition to the 650 MW already identified in the PACR.

Table 23. Approximate capacity of synchronous machines that can operate in synchronous condenser mode to provide equivalent system strength contribution to the Sydney West node as the 'Phase 2' synchronous condensers

Location of potential synchronous machines	Capacity required to be equivalent to one 'Phase 2' synchronous condenser (MW)	Capacity required to be equivalent to two 'Phase 2' synchronous condensers (MW)
Kemps Creek	450	900
Armidale	950	1,900
Darlington Point	1,700	3,400
Newcastle	500	1,000
Wellington	700	1,400

The exact amount will depend on the specific location, the critical contingency and the electrical characteristics of the project(s).

12.2.2. Grid-forming BESS for the minimum level

This MCC assessment has included 900 MW of grid-forming BESS for the minimum level. This is the maximum amount for which there are fallback system strength solutions in the event the technology is not demonstrated as technically feasible in time. If sufficient evidence emerges during an MCC reassessment process and projects materialise that provide enough certainty that fallback solutions are not required, then additional grid-forming BESS may be relied upon to displace synchronous condensers.

Following the assumptions used in this MCC assessment, approximately 950 MW of grid-forming BESS provides the equivalent fault current to one minimum level 'Phase 2' synchronous condenser (or 1,900 MW for two synchronous condensers). This grid-forming BESS would be in addition to the 900 MW already identified in this assessment.

12.2.3. Coal generator units

This MCC assessment has included two coal generator unit retirement scenarios. Under both scenarios, Bayswater and Vales Point coal units are retired by FY34. If both Bayswater and Vales Point units were to delay their retirement dates beyond FY34, and it is likely that AEMO would include this in the Step Change scenario via a subsequent IASR or ISP update,¹⁰⁷ then we expect this would commensurately defer the need for additional system strength solutions.

Extended coal retirement dates are not expected to change the preferred portfolio composition in isolation, only the timing of the 'Phase 2' synchronous condensers and level of hydro and gas re-dispatch. However, deferred investment does provide additional time for alternative solutions, including grid-forming BESS or emerging synchronous machines with synchronous condenser capability, to demonstrate feasibility.

Importantly, this assessment assumes a similar level of coal unit reliability and operational output could be maintained if coal retirements extend. As noted in Section 2.2.2, AEMO has identified that ageing coal

¹⁰⁷ [Regulatory investment test for transmission application guidelines](#), AER, November 2024, Section 3.4

generators present an increasing risk of unavailability and that more flexible operating practices of coal units (expected as the penetration of renewables increases) can accelerate equipment degradation.

The lead time for synchronous condensers to be fully commissioned and in-service is significant, driven by the high international demand for this equipment. Given this, the decision to procure must be made well-ahead of the three-and-a-half-year notice period required by coal generator unit proponents before their retirement. To impact the preferred portfolio, coal units must provide notice of changes to their planned retirement date and be included (or expected to be included) in AEMO's next ISP Step Change scenario. This would need to occur prior to Transgrid submitting a contingent project application for the 'Phase 2' synchronous condensers.

13. Next steps for managing system strength requirements

13.1. Consultation

Transgrid has completed a one-month consultation period on the draft MCC assessment, consistent with the determination made by the AER. Transgrid received four submissions during this process. These submissions have been addressed in this final MCC Report. Appendix E summarises the feedback and how key matters raised have been addressed.

Transgrid thanks those involved in the consultation process during this MCC assessment, the RIT-T and during ongoing engagement for managing system strength in NSW.

13.2. Proposed next steps for system strength solutions

Transgrid will continue to investigate options to maintain flexibility as part of the next steps for the project, including working with industry to explore new non-network options that emerge which could become technically and commercially feasible and warrant a further revision to the preferred portfolio.

13.2.1. Non-network solutions

Transgrid will continue to procure non-network system strength solutions as part of a prudent and efficient portfolio, based on the latest information available at the time of procurement.

Notices for future tranches of synchronous machine and grid-forming BESS contracts will be communicated by email to all eligible parties who have previously submitted an expression of interest (EOI).

If you have not previously submitted an EOI for your project(s), or there have been material changes to your project since your EOI, you may submit a new or updated EOI at any time using the documentation on Transgrid's [website](#). Please also advise Transgrid if the contact person named on your most recent EOI submission has changed.

Prior to contracting, Transgrid will undertake a detailed technical and commercial assessment. This assessment will include (where required) detailed power system analysis to select and validate additional non-network solutions required to meet minimum fault level requirements and/or achieve stable voltage waveforms, and an assessment of prudence and efficiency against the AER's System Security Network Support Payments Guideline. Transgrid expects contracts would only be offered where the project can meet the relevant technical performance requirements.

Transgrid's proposed non-network contracts are reviewed by the AER, where eligible, for prudence and efficiency before contracts are signed to ensure sufficient oversight on costs that will be passed through to consumers.

Grid-forming BESS

For the efficient level, Transgrid is currently evaluating responses to its initial tender for up to 2 GW of grid-forming BESS to support stable voltage waveform needs. Future tenders will occur as Transgrid progresses towards the PACR-identified portfolio of 5 GW, subject to holistic assessments in the contracting timeframe.

For the minimum level, Transgrid is engaging with industry, AEMO and other TNSPs to progress the assessment and validation of the technical feasibility of grid-forming BESS to provide protection quality fault current, including as an industry partner to the UNSW 'PROFILES' project.¹⁰⁸

Minimum level system strength requirements are most critical at the Sydney West node. The minimum level contribution of a project, if proven to be technically feasible, is significantly higher if the project is located on the transmission network within the Sydney West (and Newcastle) region, due to the avoidance of impedance on the distribution network and from transformers at bulk supply points. Transgrid invites proponents of grid-forming BESS located in the Sydney West region interested in supporting the technical feasibility assessment of this technology for minimum level services to get in touch via email at systemstrength@transgrid.com.au with a completed EOI form (from Transgrid's [website](#)).

Re-dispatch of synchronous generators

Transgrid has completed its initial procurement process and secured a contract for synchronous system security services for FY26 and FY27. The timing for a subsequent procurement process and potential additional contracts will be informed by additional market modelling based on a holistic assessment at the time of contracting. Transgrid invites proponents to maintain an up-to-date EOI with Transgrid for system strength services.

Transgrid welcomes EOIs from parties with solutions that include fitting clutches to existing or new synchronous machines, including hydro, coal and gas units, to enable their operation in synchronous condenser mode for the purposes of re-dispatch. Upgrades to 650 MW of synchronous machines to allow synchronous condenser mode were identified in the preferred portfolio at the PACR stage and will be assessed in the contracting timeframe.

13.2.2. Network synchronous condensers

'Phase 1' synchronous condensers, for the first five sites, have already been awarded and are outside the scope of this MCC.

Currently, the actual cost of funding projects is higher than that provided by the AER's rate of return instrument. This creates an investability issue with no clear solution under the NER. We will continue to engage with the AER to assess our options for 'Phase 2' synchronous condensers, including any flexibility that the AER may have when making a contingent project determination. Transgrid has highlighted this issue on several occasions and most recently during the AER's draft RORI consultation process.¹⁰⁹

In past large projects, Transgrid has worked with the AER and various government agencies to close the gap with additional support or alternate approval pathways, successfully reaching financial close. Transgrid plans to take the same approach for capital investments contemplated in this MCC.

¹⁰⁸ <https://arena.gov.au/projects/unsu-protection-relay-operation-for-inverter-based-low-inertia-electricity-systems-profiles-project/>

¹⁰⁹ Transgrid, 31 July 2026, Submission on draft 2026 RORI, <https://www.aer.gov.au/documents/transgrid-submission-draft-2026-rori-31-july-2026>

Appendix A. MCC assessment modelled scenario and input parameters

The table below lists key assumptions and input parameters used in this assessment.

Table 24. Key assumptions and input parameters used in this assessment

Assumption	Source for each scenario for MCC assessment	Source for PACR
Transmission development pathway	Optimal development path from AEMO's Final 2026 ISP	Optimal development path from AEMO's Final 2024 ISP
Grid-forming BESS contribution to the minimum level	Available from FY33	Available from FY33
Coal generator retirement date	Two scenarios modelled: 2026 ISP Step Change - Proponent Advised coal unit retirement dates	2024 ISP Step Change
Storage capacity outlook	2026 ISP Step Change	2024 Final ISP with revisions for New England REZ as discussed in the PACR.
Gas fuel cost	2026 ISP inputs and assumptions workbook	2024 Final ISP inputs and assumptions workbook
Gas variable operating maintenance cost	ISP inputs and assumptions workbook	2024 Final ISP inputs and assumptions workbook
Gas emissions intensity	2026 ISP inputs and assumptions workbook	2024 Final ISP inputs and assumptions workbook
Hydro variable operating maintenance cost	2026 ISP inputs and assumptions workbook	2024 Final ISP inputs and assumptions workbook
Value of emissions	2026 ISP inputs and assumptions workbook	AER Final Guidance Note May 2024
Value of customer reliability	AER Values of Customer Reliability 2025 Annual Adjustment	AER Values of Customer Reliability report 2024
Maintenance rate of synchronous condensers	Based on 'Phase 1' synchronous condenser award	Based on market sounding
Life of synchronous condenser	40 years	40 years
Capital cost of battery	2026 ISP inputs and assumptions workbook, Step Change scenario	2024 ISP inputs and assumptions workbook
Life of BESS	20 years	20 years
Commercial discount rate	7%, 2026 ISP inputs and assumptions workbook	7%, 2024 Final ISP inputs and assumptions workbook
Technology-specific real-pre-tax weighted	Transmission regulated assets: 3%	Not included, as the capitalised cost methodology for cost benefit analysis

Assumption	Source for each scenario for MCC assessment	Source for PACR
average cost of capital (WACC) estimate for regulated transmission	Battery projects: 8% 2026 ISP inputs and assumptions workbook, Step Change scenario	followed AEMO's approach in the 2024 Final ISP

Appendix B. Assessment of gas availability for system strength re-dispatch

Gas generators contribute to system strength when they are synchronised to the grid, which requires a minimum generation level to operate stably. Operating additional hours for system strength provision (termed 're-dispatch') is dependent on the availability of gas supply to each power station. Gas availability is influenced by pipeline capacity, gas supply and competing demand for gas (e.g., industrial and residential consumption). This appendix summarises the desktop assessment used to develop gas constraints which were applied in the MCC modelling (see Section 4.3.2), reflecting practical limitations in gas availability.

The PACR included a pipeline constraint on the Sydney-Newcastle pipeline, which limited coincident gas re-dispatch for units served by this pipeline. The PACR did not implement any other constraints as it was not expected to affect the ranking of portfolio options. This was because only the worst-ranking option had a material amount of gas re-dispatch, and including the constraint would have made its ranking even worse. For this MCC assessment, the gas constraints are expected to affect the ranking of portfolio options, which is why they have now been included.

Gas generators in NSW

A generator's contribution to the minimum level of system strength depends on its electrical location relative to the system strength nodes, with the need being highest surrounding Sydney West. Due to their electrical distance, some NSW gas generators provide only a small fault level contribution to these nodes, making them very high-cost on a 'cost per unit of system strength' basis. This assessment focuses on eight NSW gas units which exhibit a material system strength contribution to the Sydney West and Newcastle nodes.

NSW gas units are either open-cycle gas turbines (OCGT) or combined-cycle gas turbines (CCGT). OCGTs are typically more flexible (e.g., faster start and ramp) and are designed for peaking operation, which means they typically operate at low annual capacity factors (around 5%). CCGTs are designed to operate at higher capacity factors. Most of the NSW gas units that have a high system strength contribution to Sydney West and Newcastle nodes are OCGTs (88%), which are ill-suited to sustained operation for system strength (but are well-suited to operation during short periods of low system strength).

Limitations on gas availability for system strength

Transgrid's development of gas constraints for this analysis was based on AEMO's assessment of gas supply via its annual GSOO,¹¹⁰ as well as from advice by GHD during the PACR. AEMO was consulted during Transgrid's development of the gas constraints used in this assessment.


Two constraints were developed, to reflect the expected availability of gas for re-dispatch to meet system strength needs, driven by:

- 1) pipeline constraints: the maximum gas that can be delivered to a power station, determined by the capacity of the supplying pipeline; and
- 2) gas supply constraints: the total gas available to the system, based on total production, imports, and storage less demand from other users (e.g. industrial and residential) and gas required for electricity generation for normal energy market purposes.

¹¹⁰ Gas Statement of Opportunities 2026, AEMO, April 2026


The GSOO indicates declining production in southern Australia (SA, VIC, TAS and NSW), which means there is an increased reliance from southern states on supply from Queensland via the South West Queensland pipeline and seasonal storage. This is illustrated in the graph below from the GSOO.

Figure 29. Figure taken from AEMO's 2026 GSOO. Page 53. Actual and forecast maximum daily production capacity from southern gas fields in June, 2024-30 (TJ / d)



As gas usage in the southern states is highest in winter, this can leave storages empty during spring, which is typically a time of low system strength. This makes it more likely has re-dispatch will not be available when it is most needed for system strength. This is shown on the figure below from AEMO's Draft 2026 ISP for the Step Change scenario for 2031 based on the 2015 weather reference year.

Figure 30. Figure taken from Appendix 10 Gas Development Projects for AEMO's Draft 2026 ISP, page 31. Forecast gas storage profile for gas development project Option 3, Step Change, reference year 2015, calendar year 2031 (PJ)



Gas availability is dependent upon the level of line-pack or on-site storage. If periods of low system strength occur after a renewable lull (low coincident wind and solar event), which increases demand for gas, then this will materially affect the availability of gas supply and therefore the ability for gas generators to increase their operation for system strength. Conversely, if gas is used excessively for system strength re-dispatch, then this may jeopardise the availability of gas for energy reliability during a subsequent renewable lull.

Some NSW gas generators have secondary fuels on-site and can operate with diesel. This may increase the availability of some gas units for system strength, but is very costly, highly pollutant and subject to similar availability concerns if secondary fuels are required to meet energy reliability requirements as forecast by AEMO.¹¹¹

Forming gas constraints

To reflect the limitations above, Transgrid applied the following two constraints in the modelling:

- Limit coincident gas re-dispatch for system strength at any point in time, to reflect pipeline limitations on the Sydney–Newcastle line. This pipeline supplies gas to the bulk of the gas units in NSW which provide a material system strength contribution to the Sydney West and Newcastle regions.
- Limit total annual gas re-dispatch based on a percentage of annual energy market dispatch, to reflect gas supply limitations. This constraint becomes more stringent from FY33 as southern production declines.


Gas re-dispatch is the most expensive system strength option and is not expected to be relied on once alternative solutions are available (synchronous condensers and grid-forming BESS for the minimum level). On that basis, this analysis does not consider longer-term measures to expand gas supply or pipeline capacity. When gas re-dispatch limits are breached in the MCC analysis, periods of additional gas re-dispatch requirements are modelled as risks of gaps, leading to involuntary load curtailment (unserved energy).

Ranking of portfolio options without gas constraints

For transparency, the net market benefits without the gas constraints have been shown below for the 2026 ISP Step Change scenario.


The magnitude of net market benefits is significantly reduced, given the lower cost of gas re-dispatch relative to unserved energy. However, the ranking of portfolio options does not change either with or without grid-forming BESS. A similar decrease in net present value is observed when comparing portfolio option 3a to portfolio option 3b, justifying the decision to only treat portfolio options 3, 4 and 5 as credible.

Figure 31. 2026 ISP Step Change scenario. Net present value assessment without gas constraints, excluding grid-forming BESS



¹¹¹ [2026 ISP Appendix A.10. Gas Development Projects](#), AEMO, June 2026, Page 8

Figure 32. 2026 ISP Step Change scenario. Net present value assessment without gas constraints, including grid-forming BESS



The gas constraints do not influence the ranking of portfolio options in this MCC assessment, this further justifies the simplistic approach to setting the gas constraints to be commensurate with the analysis. However, the gas constraints do affect the magnitude of the net market benefits, indicating the sensitivity of involuntary load curtailment to gas availability.


Appendix C. Comparison of net present value methodology

Since the system strength PACR, Transgrid has aligned its approach to annualising and discounting costs with AEMO's ISP methodology.¹¹² Under this methodology, the capital investment is converted into an equivalent annual annuity to allow like-for-like comparison on assets with different economic lives and different commissioning dates. Transgrid is required to follow the assumptions used by AEMO¹¹¹ and has incorporated this methodology into this assessment. This approach changes the capital cost profile of solutions assessed under this MCC assessment compared to the PACR. In the PACR, the capital cost was modelled based on when it would be incurred by Transgrid; we refer to this as the capitalised cost methodology.

For this MCC assessment, Transgrid used AEMO's cost-benefit assessment methodology, the capital cost is spread over the economic life of the asset to reflect to how the costs would be recovered, this is referred to as the annualised cost methodology. The weighted average cost of capital is also included into the annual cost of the capital investment to reflect a regulated return on transmission assets or the techno-specific return identified by AEMO for unregulated assets. This is compared to the capitalised cost methodology (used in the PACR) which did not include a return on investment (for either regulated or unregulated).


This appendix presents the results of a net present value assessment using the capitalised cost methodology, consistent with the assessment in the PACR. The results are shown below for the Draft 2026 ISP Step Change scenario, both excluding and including grid-forming BESS for the minimum level.

Figure 33. 2026 ISP Step Change scenario. Net present value assessment with capitalised cost methodology, excluding grid-forming BESS



¹¹² [ISP methodology](#), AEMO, June 2025, Page 94

Figure 34. 2026 ISP Step Change scenario. Net present value assessment without capitalised cost methodology, including grid-forming BESS



Portfolio option 4a is the preferred option when excluding grid-forming BESS for the minimum level and Portfolio option 3b is the preferred option when including grid-forming BESS, on the condition that the commercial feasibility of 'Phase 2' synchronous condensers is resolved. This is consistent with the results of this draft MCC assessment, showing that the ranking of portfolio options is the same across both the capitalised cost and the annualised cost methodologies.

The net present value is slightly lower under the capitalised cost methodology, as the capital cost is incurred earlier. However, the reduction in net present value is relatively small (<1%) compared to the magnitude of the benefits.

Appendix D. Compliance checklist

The table below highlights which how each requirement determined by the AER in its response to Transgrid's notification of a system strength material change in circumstances has been addressed.¹¹³

Table 25. Compliance checklist of each AER requirement in its determination

Requirement	Relevant section in this Report
Undertake a streamlined cost benefit analysis, drawing on: - the existing PACR analysis - updated cost and timing information, and - the most recent AEMO ISP-related inputs and outputs and AEMO's 2025 Transition Plan for System Security, where relevant.	Streamlined cost benefit analysis has been undertaken. The methodology is described in Section 6. The most recent AEMO ISP-related inputs are currently the 2026 Final ISP.
Transgrid must publish a draft statement on its website by 24 June 2026 which sets out: - a statement that the preferred option identified remains the preferred option, as well as any supporting information necessary to demonstrate that the preferred option identified remains the preferred option; or - a statement that the preferred option is no longer the preferred option and identifying the new preferred option, as well as any supporting information necessary to demonstrate that the preferred option is no longer the preferred option and the reasons the new preferred option is the preferred option.	Transgrid published its draft MCC assessment on its website on 1 July 2026 after notification to the AER. The refined preferred portfolio option is described in Section 11 including the reasons the new preferred portfolio option is the preferred portfolio option.
Transgrid must publish a draft statement on its website by 24 June 2026 which sets out: provides supporting information setting out the range of all potential solutions which could reasonably be expected to provide system strength, as well as reasons why any potential options were not considered credible or are considered to not form part of the preferred portfolio option.	The solutions considered in this MCC assessment are described in Section 3.
Transgrid must publish a draft statement on its website by 24 June 2026 which sets out: provides a description of each of the changes in circumstances, including the changed operation of synchronous generation, and its materiality to the analysis, and	The nature of each material change in circumstance addressed in this assessment is described in Section 2.
Transgrid must publish a draft statement on its website by 24 June 2026 which sets out: presents the updated cost benefit analysis developed under paragraph	The updated cost benefit analysis results are described in Section 8 and the attached NPV workbooks.
Transgrid must seek submissions from registered participants, AEMO and interested parties on the preferred option presented and the issues addressed in the draft statement. The period for submissions must be 1 month from the date Transgrid publishes the draft statement on its website.	Transgrid conducted a one-month consultation period from 1 July 2026 to 1 August 2026. The submissions have been published on Transgrid's website and addressed in this report. Appendix E summarises the key

¹¹³ [Material change in circumstances – Meeting system strength requirements in NSW – Determination](#), AER, June 2026

Requirement	Relevant section in this Report
	matters and how they have been addressed.
Transgrid must publish a final statement which sets out the matters required under paragraph (2), incorporates feedback from submissions and provides a summary of, and response to, submissions received during the consultation period. The final statement must be published on Transgrid's website within 1 month of the closing date for submissions, at the latest by 24 August 2026.	Transgrid has published this final MCC Report on 24 August 2026.

Appendix E. Details of non-confidential points raised in consultation on the draft MCC Report

Transgrid received formal submissions from four parties directly in response to the draft MCC Report consultation period occurring from 1 July 2026 to 1 August 2026. The submissions have been published on our website alongside this Report.

The parties who submitted are:

- Andritz Hydro – a supplier of synchronous condensers that participated in Transgrid's 'Phase 1' procurement process.
- Castle Group – a BESS proponent that is developing a portfolio of BESS in NSW, including a 1,000 MW / 4,000 MWh, four-hour BESS at Kemps Creek (with targeted commercial operation in January 2030) as well as a second four-hour grid-forming BESS of up to 900 MW / 3,600 MWh at Regentville.
- Lake Lyell Pumped Hydro – a 385 MW / 8 hour pumped hydro energy storage joint venture project under development near Lithgow between EDF Power Solutions Australia and EnergyAustralia.
- Several members of Transgrid's Consumer Advisory Group (CAG) – our expert consumer-focused advisory body that provides informed consumer insights on a range of key issues across the energy sector.¹¹⁴

The submissions focused generally on:

- Support for the reassessment of the preferred portfolio, including the revision of the number of 'Phase 2' synchronous condensers from five to three.
- Providing additional information on emerging system strength solutions, including the Lake Lyell Pumped Hydro facility and a portfolio of grid-forming BESS projects.
- The importance of preserving flexibility to pivot from synchronous condensers to alternative solutions (e.g. new synchronous machines with synchronous condenser capability and grid-forming BESS once proven technically feasible for the minimum level of system strength) and if in the interest of consumers.
- Further clarity of requirements for grid-forming BESS to demonstrate technical feasibility for the minimum level.

The key points raised in submissions are summarised and responded to in Table 26 below.

¹¹⁴ Members of Transgrid's Consumer Advisory Group who have lodged this submission are Louise Benjamin, Gavin Dufty and Mary Karras.

Table 26. Transgrid response to submissions to the draft MCC Report

Summary of comment(s)	Submitter(s)	Our response
Interaction between the delayed synchronous condenser delivery and the use of coal units		
Clarify whether the assessment considers the potential need for coal generator units to extend operation due to delayed synchronous condenser delivery, including the impacts on the wholesale electricity market and investment signals for new generation, storage and network assets.	Several members of CAG, p. 1.	This MCC assessment has used AEMO's Step Change scenario retirements dates to inform its core analysis, given that this scenario drives Transgrid's system strength obligations. However, the assessment also considers another potential scenario, which is where coal units retire at proponent announced dates, driven by proponent decisions. Results show that if sufficient system strength solutions cannot be delivered ahead of coal generator retirements, then the risk of system strength gaps occurs; in this case, intervention may be required to ensure the grid may be safely and securely operated. This would impact upon wholesale markets and investment signals for new generation, storage and network assets. These impacts have not been modelled. In progressing next steps for 'Phase 2' synchronous condensers and non-network solutions, Transgrid will continue to monitor for market updates on coal retirement dates. Changes to coal retirement dates may affect the optimal portfolio, as shown by the difference in the risk of systems strength gaps identified between FY31 and 33 under the ISP Step Change and Proponent Announced coal retirement dates.
The acceleration of synchronous condensers		
Acceleration should not be framed only as all three synchronous condensers or none.	Several members of CAG, p. 2.	Following on from this MCC assessment, Transgrid will assess options to resolve the commercial feasibility of 'Phase 2' synchronous condensers. Investigations into the potential for acceleration will still be considered, either in full or partial.

The assessment should detail the risks of both committing too early to synchronous condensers, as well as waiting too long to commit. <i>and</i> The acceleration options should be compared to the NER pathway, including in terms of the costs, timing, risks and consumer protections associated with each approach.	Several members of CAG, p. 2.	As set out in case study 1 in section 9.1, we consider there to be significant asymmetric risk regarding system strength adequacy following the retirement of Bayswater and Vales Point, and external factors could force a situation where coal unit retirements occur before replacement solutions are delivered. This case study reinforces the importance of timely delivery of system strength solutions ahead of key transition points to enable these key expected changes to be appropriately managed. The acceleration of ‘Phase 2’ synchronous condensers is modelled to close the risk of gaps observed in FY31-33 under the AEMO 2026 ISP Step Change scenario. Noting the risk of gaps is not observed under the Proponent Advised timing, there exists uncertainty into the size and timing of the need. We note that synchronous condenser costs are significant, with consumers paying for these costs amortised over the life of the asset. Non-network solutions could provide lower cost alternatives under the RIT-T framework where they are assumed to enter the energy market under the base case (i.e., they meet the definition of ‘committed’ or ‘anticipated’ under the RIT-T).¹¹⁵ Noting that the RIT-T and MCC assessment uses underlying economic cost, rather than contract price, Transgrid will submit an ex-ante application to the AER to assess prudence and efficiency of proposed contracts prior to entering into commercial arrangements with non-network providers. There is therefore a current tension between: • committing to ‘Phase 2’ synchronous condensers in the short-term to mitigate the significant downside risk of there being insufficient system strength following the retirement of Bayswater and Vales Point;¹¹⁶ and • waiting to see whether sufficient non-network solutions reach ‘committed’ or ‘anticipated’ status under the RIT-T and can replace synchronous condensers as lower cost solutions. The long lead-time of synchronous condenser solutions provides a timing challenge, where committing to synchronous condensers early provides greater certainty that system strength requirements can be met when required, but may result in investment that could subsequently be supplemented or displaced by lower cost non-network solutions. Non-network options may be lower cost if they eventuate, but there are very significant system security impacts if they do not eventuate and ‘Phase 2’ synchronous condensers are not procured. Given the range of uncertainties that remain at this stage, it is difficult to precisely determine the specific date by which a decision to commit to the ‘Phase 2’ synchronous condenser solution would need to be made. At this stage, the cost of finance for the ‘Phase 2’ synchronous condensers is above the compensation provided under the existing regulatory arrangements. The next step is to explore how the gap between the actual cost of finance and the compensation can be closed. Acceleration of ‘Phase 2’ synchronous condensers is not currently a feasible option and has been presented in this
--	--------------------------------------	---

Summary of comment(s)	Submitter(s)	Our response
		analysis to demonstrate the benefit, <i>if</i> acceleration was to be possible. As such, we have maintained consistency in the underlying economic cost of synchronous condensers. However, we strongly encourage non-network proponents to engage with Transgrid regarding <i>additional</i> non-network solutions (i.e., those that may potentially lead to a reduction in the number of 'Phase 2' synchronous condensers within the preferred portfolio). This is in addition to the <i>core</i> non-network solutions already included in the preferred option (e.g., the 900 MW of BESS for the minimum level, the 5 GW of BESS for the efficient level and the 650 MW of upgrades to synchronous machine to allow synchronous condenser mode). Refer to Section 12.1 for additional details on requirements for changes to the preferred portfolio, which could then be incorporated within a new MCC assessment.
Emerging non-network system strength solutions		
The proposed Lake Lyell Pumped Hydro should be recognised and progressed as a market-led, non-network alternative solution for displacing one of the two Sydney/Newcastle 'Phase 2' synchronous condensers.	Lake Lyell Pumped Hydro, p. 1.	Based on the information provided, the proposed Lake Lyell Pumped Hydro does not currently meet the criteria for being considered 'anticipated' or 'committed' under the RIT-T (and note that it is currently classified as 'publicly announced' by AEMO). This comment therefore also applies to other synchronous projects (such as hydro and gas) that have the status of 'publicly announced' by AEMO. At this point in time, we have therefore not explicitly modelled Lake Lyell Pumped Hydro as part of the MCC assessment. If included, it would need to be assessed at its full capital and operating costs under the RIT-T, and it is not expected to provide commensurately more market benefits or system strength than a synchronous condenser (which makes it an inferior solution to those included in the preferred portfolio). We will continue to engage with Lake Lyell Hydro and monitor its progress towards becoming a technically and commercially feasible non-network solution to help meet NSW's system strength requirements. Subject to the timing of its development and its ability to provide the required system strength services, the Lake Lyell Pumped Hydro facility could be assessed to be included within the preferred option if it progresses to 'anticipated' or 'committed' status sufficiently early. Alternatively, depending on timing, it may instead be considered as a candidate for the re-dispatch of synchronous machines component of the preferred option.

¹¹⁵ While these solutions present as low cost under the RIT-T framework, given they are assumed to proceed under the base case, they also typically involve network support payments to the proponents where they are included in the preferred option. While these network support payments are passed through to end customers (and thus are a real cost), they have no bearing on the outcome of the RIT-T assessment under the RIT-T framework.

¹¹⁶ Note that there are additional benefits of deploying 'Phase 2' synchronous condensers ahead of the retirement of Bayswater and Vales Point, including reducing the need for additional gas and hydro re-dispatch and mitigating the risks of unexpected outages, coinciding maintenance periods and periods of economic decommitment or changed operational behaviours (e.g. two-shifting).

Summary of comment(s)	Submitter(s)	Our response
The portfolio of proposed BESS should be assessed.	Castle Group, p. 3.	Based on the information provided, the proposed BESS do not currently meet the criteria for being considered 'anticipated' or 'committed' under the RIT-T (and note that the two specific projects mentioned are currently classified as 'publicly announced' by AEMO). At this point in time, we have therefore not explicitly modelled them as part of the MCC assessment. Rather, the BESS proposed by Castle Group are captured in the assessment through the consideration of generic BESS, which represent future ISP BESS that do not yet have a proponent (or where projects are not sufficiently advanced). We note that, in the contracting timeframe, individual projects will be eligible to participate in the relevant tenders. We encourage all potential non-network proponents to maintain an up-to-date EOI with Transgrid.
The portfolio of proposed BESS should be assessed before Transgrid lodges its 'Phase 2' contingent project application.	Castle Group, p. 3.	Transgrid has identified that if additional technically and commercially feasible non-network options emerge, the optimal portfolio could be revised to further increase net market benefits and potentially reduce the number of 'Phase 2' synchronous condensers. For this to occur, feasible non-network options would need to be assessed and then selected within the preferred portfolio prior to Transgrid's lodgement of a contingent project application for 'Phase 2' synchronous condensers. Under the 'assumed' synchronous delivery timeline, this occurs in late-2027. That said, Transgrid will also explore options in the procurement timeframe to enable changes to the preferred portfolio even after lodgement of a contingent project application, if in the interest of consumers.

Transgrid will inform stakeholders whenever there is updated evidence impacting on the findings of the MCC assessment, via our website and email correspondence with EOI proponents.

Summary of comment(s)	Submitter(s)	Our response
The ability of grid-forming BESS to assist with meeting the minimum level		
Castle Group offers to contribute to the testing of the technical feasibility of BESS to meet the minimum level in several ways.	Castle Group, p. 3.	Transgrid welcomes the proposal of Castle Group to contribute to the testing of the technical feasibility of BESS to meet the minimum level. Refer to Section 0 for further information.
Ensuring flexibility in the preferred option to enable Transgrid to pivot if that is optimal		
Transgrid should identify opportunities to preserve optionality, including assessing break costs or option-style procurement approaches to maintain flexibility to pivot to possible future lower-cost alternatives and manage stranded asset risk for long-lead-time equipment with long asset lives.	Several members of CAG, p. 2.	Transgrid has put in place measures, and will continue to refine, to maintain flexibility of the preferred portfolio to manage uncertainty of the system strength need and possible future alternative solutions. This is prudent given the extended lead time of 'Phase 2' synchronous condensers necessitating procurement well-ahead of the need materialising to ensure there are sufficient system strength solutions available. Transgrid will also explore options in the contracting timeframe and continue to monitor future MCCs.

Summary of comment(s)	Submitter(s)	Our response
Expected cost and availability of synchronous condensers		
Concerned to see that the average cost per site for design and construct is \$225 million/site.	Andritz Hydro, p. 1.	In April 2026, Transgrid submitted a revenue proposal to the AER for its accelerated 'Phase 1' synchronous condensers project (the first five of the synchronous condensers identified in the PACR). The costs reported for the synchronous condenser solutions (i.e. an average cost of \$225 million (\$FY25) per site) reflects the total estimated cost of delivering the solution, including supply of the synchronous condenser unit, as well as associated balance of plant equipment, enabling works and site civil works required to facilitate its installation and operation. The synchronous condenser provider and civil and enabling works providers were selected through a competitive procurement process undertaken by Transgrid. The procurement process was deemed by the AER to be the result of a genuine and appropriate procurement process under the NSW EII Act.¹¹⁷ The average cost of \$225 million (\$FY25) per site compares to an estimated average cost of \$163 million (\$FY25) modelled in the PACR (equivalent to a 38% increase against the central estimate or a 6% increase against the upper range of the estimate).¹¹⁸ The increase was driven by the continued escalation of global demand and supply constraints for this equipment, as power systems worldwide transition away from fossil fuels to renewable energy. Transgrid expects that the total project cost to deliver 'Phase 2' synchronous condensers will increase beyond the cost of the accelerated 'Phase 1' synchronous condensers, due to ongoing market constraints and further supply chain impacts from the conflict in the Middle East. The expected average cost for 'Phase 2' synchronous condensers is now \$324 million (\$FY25), based on a Class 4 estimate (-30%, +40%). Transgrid welcomes Andritz Hydro's continued interest in supporting the next phase of system strength solutions. Transgrid will consider a range of options for the delivery of 'Phase 2' solutions, including potential technology providers, having regard to the requirements of the preferred portfolio, market conditions, delivery timeframes and the outcomes of the RIT-T process.

¹¹⁷ [System strength project 2026-31 revenue proposal](#), Transgrid, April 2026, Page 49

¹¹⁸ The average cost presented in the PACR was \$160 million, in \$FY24, with actual costs estimated to be within -20% to +30% of the base capital cost estimate (i.e. \$128 million to \$208 million range, in \$FY24). This cost is adjusted for inflation to enable a comparison in \$FY25.

Summary of comment(s)	Submitter(s)	Our response
Clarify whether different synchronous condenser sizes were considered in Transgrid's cost and availability assumptions for 'Phase 2' synchronous condensers (e.g., multiple smaller synchronous condensers, as procured for the 'Phase 1' accelerated synchronous condensers pursuant to the PNIP Direction, versus a single larger synchronous condenser). <i>and</i> Clarify whether the longer delivery timeframe for the 'Phase 2' synchronous condensers has created a different set of synchronous condenser options (e.g., different original equipment manufacturers, products, sizes etc), compared with the 'Phase 1' synchronous condensers.	Several members of CAG, p. 1.	The assumptions used to represent 'Phase 2' synchronous condensers in this MCC assessment has been informed by the 'Phase 1' procurement process, which was open to all types of synchronous condensers. Specifically, the procurement process for 'Phase 1' allowed different synchronous condensers sizes or combinations which could provide fault current within a target range. This ensured Transgrid received the best price by enabling a broader range of products to be considered. The longer delivery timeframe for the 'Phase 2' synchronous condensers has not directly created a different set of synchronous condenser options, compared with the 'Phase 1' synchronous condensers, for this MCC assessment.

Summary of comment(s)	Submitter(s)	Our response
Other miscellaneous points		
Transgrid should provide a plain English description of the risk of insufficient system strength.	Several members of CAG, p. 2.	Transgrid has produced a plain English factsheet to describe Transgrid's plan to maintain sufficient system strength in NSW. This can be found here: https://www.transgrid.com.au/media/dmoj2np5/keeping-our-renewables-grid-stable.pdf The risk of insufficient system strength is also explained in Transgrid's RIT-T documentation, including in section F.3 (p137) of the PACR, which describes the base case or counterfactual scenario where no action is taken to meet NSW's system strength requirements. <i>Under the base case, where no action is taken to meet NSW's minimum and efficient level system strength requirements, there would be a significant deficit in system strength because of retiring coal generation and growing renewable connections. In this hypothetical future, it is expected that AEMO would direct existing synchronous generators to operate, or to constrain renewable generation (where possible) to maintain system security. If the efficient level of system strength is not met, the remaining renewable generation that is able to operate securely may be insufficient to meet system demand, which may lead to load shedding.</i> <i>If the minimum level of system strength is not met, voltage control and protection systems may not operate correctly, leading to cascading failures in the transmission network and, in the worst case, widespread and extensive power outages.</i>
Transgrid should acknowledge that grid forming inverters are a technically feasible alternative to synchronous condensers and warrant detailed analysis as part of Transgrid's optionality considerations.	Castle Group, p. 4.	Transgrid agrees that grid-forming inverters are a potential alternative to synchronous condensers. However, detailed analysis is still required to confirm their technical feasibility (as outlined in the body of this Report). The pathway forward outlined in this final MCC Report (and the draft report) provides opportunity for these solutions to replace synchronous condensers in the future if certain conditions are met (as outlined in Section 12).
Castle Group proposes a BESS operating envelope, monitored by SCADA, in which the reserved system-strength duty and the merchant envelope are defined and mutually exclusive in every interval - so the contracted service is demonstrably additive to the mandated baseline and cannot be double-counted.	Castle Group, p. 4.	We note the proposed mechanism to create a BESS operating envelope to manage reserved system strength duty. Any such arrangements would be handled commercially by Transgrid in the contracting timeframe. At this stage however, Transgrid's view is that the provision of stable voltage waveform support from grid-forming batteries does not require active power reservation.